

RCW 57.02.100 Single-family homes and townhouses—Multipurpose fire sprinkler systems. (1) A water-sewer district may not prohibit the use of multipurpose fire sprinkler systems that are part of a structure's plumbing system for single-family homes and townhouses as defined by the state residential building code or require a separate water meter or backflow preventer for the multipurpose fire sprinkler system.

(2) For the purposes of this section, "multipurpose fire sprinkler system" means a fire sprinkler system that:

- (a) Is supplied only by the purveyor's water;
- (b) Does not have a fire department pumper connection;
- (c) Is constructed of approved potable water piping and materials to which sprinkler heads are attached; and
- (d) Terminates at a connection to a toilet or other plumbing fixture to prevent stagnant water. [2016 sp.s. c 14 s 1.]