

**(Effective until July 1, 2020)**

**WAC 51-11C-40510      Section C405.10—Controlled receptacles.**

**C405.10 Controlled receptacles.** At least 50 percent of all 125 volt 15- and 20-ampere receptacles installed in private offices, open offices, conference rooms, rooms used primarily for printing and/or copying functions, break rooms, individual workstations and classrooms, including those installed in modular partitions and modular office workstation systems, shall be controlled as required by this section. In rooms larger than 200 square feet ( $19 \text{ m}^2$ ), a controlled receptacle shall be located within 72 inches (1.8 m) of each uncontrolled receptacle. Controlled receptacles shall be visibly differentiated from standard receptacles and shall be controlled by one of the following automatic control devices:

1. An occupant sensor that turns receptacle power off when no occupants have been detected for a maximum of 20 minutes.
2. A time-of-day operated control device that turns receptacle power off at specific programmed times and can be programmed separately for each day of the week. The control device shall be configured to provide an independent schedule for each portion of the building not to exceed 5,000 square feet ( $465 \text{ m}^2$ ) and not to exceed one full floor. The device shall be capable of being overridden for periods of up to two hours by a timer accessible to occupants. Any individual override switch shall control the controlled receptacles for a maximum area of 5,000 square feet ( $465 \text{ m}^2$ ). Override switches for controlled receptacles are permitted to control the lighting within the same area.

**EXCEPTION:** Receptacles designated for specific equipment requiring 24-hour operation, for building maintenance functions, or for specific safety or security equipment are not required to be controlled by an automatic control device and are not required to be located within 72 inches (1.8 m) of a controlled receptacle.

[Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40510, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-40510, filed 2/1/13, effective 7/1/13.]

**(Effective July 1, 2020)**

**WAC 51-11C-40510      Section C405.10—Controlled receptacles.**

**C405.10 Controlled receptacles.** At least 50 percent of all 125 volt 15- and 20-ampere receptacles installed in private offices, open offices, conference rooms, rooms used primarily for printing and/or copying functions, break rooms, individual workstations and classrooms, including those installed in modular partitions and modular office workstation systems, shall be controlled as required by this section. In rooms larger than 200 square feet ( $19 \text{ m}^2$ ), a controlled receptacle shall be located within 72 inches (1.8 m) of each uncontrolled receptacle. Controlled receptacles shall be visibly differentiated from standard receptacles and shall be controlled by one of the following automatic control devices:

1. An occupant sensor that turns receptacle power off when no occupants have been detected for a maximum of 20 minutes.
2. A time-of-day operated control device that turns receptacle power off at specific programmed times and can be programmed separately for each day of the week. The control device shall be configured to

provide an independent schedule for each portion of the building not to exceed 5,000 square feet ( $465\text{ m}^2$ ) and not to exceed one full floor. The device shall be capable of being overridden for periods of up to two hours by a timer in a location with access to occupants. Any individual override switch shall control the controlled receptacles for a maximum area of 5,000 square feet ( $465\text{ m}^2$ ). Override switches for controlled receptacles are permitted to control the lighting within the same area.

EXCEPTION: Receptacles designated for specific equipment requiring 24-hour operation, for building maintenance functions, or for specific safety or security equipment are not required to be controlled by an automatic control device and are not required to be located within 72 inches (1.8 m) of a controlled receptacle.

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-40510, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40510, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-40510, filed 2/1/13, effective 7/1/13.]