

WAC 296-307-36627 Must the path to ground be continuous? The path to ground from circuits, equipment, and enclosures must be permanent and continuous.

[WSR 97-09-013, recodified as § 296-307-36627, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-36627, filed 10/31/96, effective 12/1/96.]