Table B103(9)—School and warehouse occupan-

cies.

| Hour of Day (time) | | Schedule for Occupancy <i>Percent of</i> Maximum Load | | | Schedule for Lighting ^{b/} Receptacle <i>Percent of</i> Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water <i>Percent of</i> Maximum Load | | | Schedule for Elevator <i>Percent of</i> Maximum Load | | |
|--------------------|-----------|---|-------|-------|--|-----------------|-------|-----------------------------|-------|-------|--|-------|-------|--|-------|-------|
| | | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 | (12-1am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 2 | (1-2am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 3 | (2-3am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 4 | (3-4am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 5 | (4-5am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 6 | (5-6am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 7 | (6-7am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 3 | 3 | 0 | 0 | 0 |
| 8 | (7-8am) | 5 | 0 | 0 | 30 | 5 | 5 | On | Off | Off | 10 | 3 | 3 | 0 | 0 | 0 |
| 9 | (8-9am) | 75 | 10 | 0 | 60/85 | 15 | 5 | On | On | Off | 34 | 3 | 5 | 30 | 0 | 0 |
| 10 | (9-10am) | 90 | 10 | 0 | 65/95 | 15 | 5 | On | On | Off | 60 | 5 | 5 | 30 | 0 | 0 |
| 11 | (10-11am) | 90 | 10 | 0 | 65/95 | 15 | 5 | On | On | Off | 63 | 5 | 5 | 30 | 0 | 0 |
| 12 | (11-12pm) | 80 | 10 | 0 | 65/95 | 15 | 5 | On | On | Off | 72 | 5 | 5 | 30 | 0 | 0 |
| 13 | (12-1pm) | 80 | 10 | 0 | 55/80 | 15 | 5 | On | On | Off | 79 | 5 | 5 | 30 | 0 | 0 |
| 14 | (1-2pm) | 80 | 0 | 0 | 55/80 | 5 | 5 | On | Off | Off | 83 | 3 | 5 | 30 | 0 | 0 |
| 15 | (2-3pm) | 80 | 0 | 0 | 55/80 | 5 | 5 | On | Off | Off | 61 | 3 | 3 | 30 | 0 | 0 |
| 16 | (3-4pm) | 45 | 0 | 0 | 50/70 | 5 | 5 | On | Off | Off | 65 | 3 | 3 | 15 | 0 | 0 |
| 17 | (4-5pm) | 15 | 0 | 0 | 35/50 | 5 | 5 | On | Off | Off | 10 | 3 | 3 | 0 | 0 | 0 |
| 18 | (5-6pm) | 5 | 0 | 0 | 35/50 | 5 | 5 | On | Off | Off | 10 | 3 | 3 | 0 | 0 | 0 |
| 19 | (6-7pm) | 15 | 0 | 0 | 35 | 5 | 5 | On | Off | Off | 19 | 3 | 3 | 0 | 0 | 0 |
| 20 | (7-8pm) | 20 | 0 | 0 | 35 | 5 | 5 | On | Off | Off | 25 | 3 | 3 | 0 | 0 | 0 |
| 21 | (8-9pm) | 20 | 0 | 0 | 35 | 5 | 5 | On | Off | Off | 22 | 3 | 3 | 0 | 0 | 0 |
| 22 | (9-10pm) | 10 | 0 | 0 | 30 | 5 | 5 | On | Off | Off | 22 | 3 | 3 | 0 | 0 | 0 |
| 23 | (10-11pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 12 | 3 | 3 | 0 | 0 | 0 |
| 24 | (11-12am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 9 | 3 | 3 | 0 | 0 | 0 |
| Fotal/Day | | 710 | 50 | 0 | 750/990 | 170 | 120 | 1500 | 500 | 0 | 691 | 80 | 84 | 285 | 0 | 0 |
| Total/Week | | | 36.00 | hours | | 40.40/ 52.40 | hours | | 80.00 | hours | | 36.19 | hours | | 14.25 | hours |
| Total/Year | | | 1877 | hours | | 2101/ 2732 | hours | | 4171 | hours | | 1887 | hours | | 743 | hours |

Table B103(9) School Occupancy^a

Wk = Weekday
Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5 percent emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0 percent when occupancy is 0 percent.
These values may be used only if actual schedules are not known.

b Lighting profiles are modified to reflect the requirement for occupancy sensors in Section C405.2.

> Table B103(10) Warehouse Occupancy^a

| Hour of Day (time) | | Schedule for Occupancy <i>Percent of</i> Maximum Load | | | Schedule for Lighting ^b / Receptacle <i>Percent of</i> Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water <i>Percent of</i> Maximum Load | | | Schedule for Elevator <i>Percent of</i> Maximum Load | | |
|--------------------|----------|---|-----|-----|---|-----|-----|-----------------------------|-----|-----|--|-----|-----|--|-----|-----|
| | | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 1 | (12-1am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 2 | 2 | 2 | 0 | 0 | 0 |
| 2 | (1-2am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 2 | 2 | 2 | 0 | 0 | 0 |
| 3 | (2-3am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 2 | 2 | 2 | 0 | 0 | 0 |
| 4 | (3-4am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 2 | 2 | 2 | 0 | 0 | 0 |
| 5 | (4-5am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 5 | 2 | 2 | 0 | 0 | 0 |

| Hour of Day (time) | | Schedule for Occupancy <i>Percent of</i> Maximum Load | | | Schedule for Lighting ^{b/} Receptacle <i>Percent of</i> Maximum Load | | | Schedule for HVAC System | | | Schedule for Service Hot Water <i>Percent of</i> Maximum Load | | | Schedule for Elevator <i>Percent of</i> Maximum Load | | |
|--------------------|------------|---|-------|-------|--|-----------------|-------|-----------------------------|-------|-------|--|-------|-------|--|------|-------|
| | | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun | Wk | Sat | Sun |
| 6 | (5-6am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 7 | 2 | 2 | 0 | 0 | 0 |
| 7 | (6-7am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 7 | 2 | 2 | 0 | 0 | 0 |
| 8 | (7-8am) | 15 | 0 | 0 | 25/40 | 5 | 5 | On | Off | Off | 10 | 2 | 2 | 0 | 0 | 0 |
| 9 | (8-9am) | 70 | 20 | 0 | 45/70 | 8 | 5 | On | On | Off | 30 | 6 | 2 | 0 | 0 | 0 |
| 10 | (9-10am) | 90 | 20 | 0 | 55/90 | 24 | 5 | On | On | Off | 36 | 12 | 2 | 0 | 0 | 0 |
| 11 | (10-11am) | 90 | 20 | 0 | 55/90 | 24 | 5 | On | On | Off | 36 | 12 | 2 | 30 | 0 | 0 |
| 12 | (11-12pm) | 90 | 20 | 0 | 55/90 | 24 | 5 | On | On | Off | 46 | 17 | 2 | 0 | 0 | 0 |
| 13 | (12-1pm) | 50 | 10 | 0 | 50/80 | 5 | 5 | On | On | Off | 57 | 4 | 4 | 0 | 0 | 0 |
| 14 | (1-2pm) | 85 | 10 | 0 | 55/90 | 5 | 5 | On | On | Off | 43 | 4 | 4 | 0 | 0 | 0 |
| 15 | (2-3pm) | 85 | 10 | 0 | 55/90 | 5 | 5 | On | On | Off | 38 | 2 | 2 | 0 | 0 | 0 |
| 16 | (3-4pm) | 85 | 10 | 0 | 55/90 | 5 | 5 | On | On | Off | 40 | 2 | 2 | 40 | 0 | 0 |
| 17 | (4-5pm) | 20 | 0 | 0 | 55/90 | 5 | 5 | On | Off | Off | 30 | 2 | 2 | 0 | 0 | 0 |
| 18 | (5-6pm) | 0 | 0 | 0 | 30 | 5 | 5 | Off | Off | Off | 18 | 2 | 2 | 0 | 0 | 0 |
| 19 | (6-7pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 20 | (7-8pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 21 | (8-9pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 22 | (9-10pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 23 | (10-11pm) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| 24 | (11-12am) | 0 | 0 | 0 | 5 | 5 | 5 | Off | Off | Off | 3 | 2 | 2 | 0 | 0 | 0 |
| Total/D | Total/Day | | 120 | 0 | 600/915 | 180 | 120 | 1000 | 800 | 0 | 429 | 91 | 52 | 70 | 0 | 0 |
| Total/W | Total/Week | | 35.20 | hours | | 33.00/ 48.75 | hours | | 58.00 | hours | | 22.88 | hours | | 3.50 | hours |
| Total/Year | | | 1835 | hours | | 1716/ 2542 | hours | | 3024 | hours | | 1193 | hours | | 182 | hours |

Wk = Weekday

a Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5 percent emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0 percent when occupancy is 0 percent. These values may be used only if actual schedules are not known.
b Lighting profiles are modified to reflect the requirement for occupancy sensors in Section C405.2.

[Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-71039, filed 2/1/13, effective 7/1/13.]