

WAC 296-150C-1150 Hallways. (1) Hallways in structures required to meet accessibility standards must have a minimum horizontal dimension that conforms to accessibility standards set by the International Building Code, current edition, standards set in the accessibility standard in WAC 296-150C-0800 (1)(d).

(2) Hallways in nonaccessible construction site trailers must have a minimum horizontal dimension of 32 inches.

[Statutory Authority: Chapter 43.22 RCW. WSR 12-15-061, § 296-150C-1150, filed 7/17/12, effective 9/1/12. Statutory Authority: Chapter 43.22 RCW and 2003 c 291. WSR 05-01-102, § 296-150C-1150, filed 12/14/04, effective 2/1/05. Statutory Authority: RCW 43.22.340, [43.22.]355, [43.22.]360, [43.22.]432, [43.22.]440 and [43.22.]480. WSR 96-21-146, § 296-150C-1150, filed 10/23/96, effective 11/25/96.]