

WAC 296-150C-1430 Gas piping system openings. All openings in the gas piping system must be closed gas-tight with threaded pipe plugs or pipe caps.

[Statutory Authority: RCW 43.22.340, [43.22.]355, [43.22.]360, [43.22.]432, [43.22.]440 and [43.22.]480. WSR 96-21-146, § 296-150C-1430, filed 10/23/96, effective 11/25/96.]