

WAC 296-307-41029 Construction and installation of atmospheric vaporizers. Atmospheric vaporizers using heat from the ground or surrounding air must be installed as follows:

- (1) Buried underground; or
- (2) Located inside the building near where the pipe enters the building, if the capacity of the unit does not exceed one quart;
- (3) Vaporizers of less than one quart capacity heated by the ground or surrounding air, may be installed without safety-relief valves if tests show that the assembly is safe.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-41029, filed 10/20/20, effective 11/20/20. WSR 97-09-013, recodified as § 296-307-41029, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-41029, filed 10/31/96, effective 12/1/96.]