

WAC 51-11C-40322 Section C403.2.2—Ventilation and exhaust.

C403.2.2

Ventilation and exhaust.

C403.2.2.1 Ventilation. Ventilation, either natural or mechanical, shall be provided in accordance with Chapter 4 of the *International Mechanical Code*. Where mechanical ventilation is provided, the system shall be configured to provide no greater than 150 percent of the minimum outdoor air required by Chapter 4 of the *International Mechanical Code* or other applicable code or standard, whichever is greater.

EXCEPTIONS:

1. The mechanical system may supply outdoor air at rates higher than the limit above when it is used for particulate or VOC dilution, economizer, night flushing, dehumidification, pressurization, exhaust make-up, or other process air delivery. Outdoor air shall be reduced to the minimum ventilation rates when not required for the preceding uses.
2. Air systems supplying Group R-1, R-2 or I-2 occupancies.
3. Alterations that replace less than half of the total heating and cooling capacity of the system.
4. Systems with energy recovery complying with the requirements of Section C403.7.6.1 that utilize sensible only active chilled beams for space cooling without any additional zonal fan power. Active chilled beams shall be permitted to utilize the increased outdoor airflow to increase space sensible capacity and to maintain space latent cooling loads without additional controls to reduce the outdoor airflow to each zone.

C403.2.2.2 Exhaust. Exhaust shall be provided in accordance with Chapters 4 and 5 of the *International Mechanical Code*. Where exhaust is provided, the system shall be configured to provide no greater than 150 percent of the minimum exhaust air required by Chapters 4 and 5 of the *International Mechanical Code* or other applicable code or standard, whichever is greater.

EXCEPTIONS:

1. The mechanical system may exhaust air at rates higher than the limit above when it is used for particulate or VOC dilution, economizer, night flushing, dehumidification, pressure equalization, relief, or other process exhaust air requirements. Outdoor air and exhaust air shall be reduced to the minimum ventilation rates when not required for the preceding uses.
2. Domestic range hood exhaust in Group R occupancies.
3. Exhaust from Group I occupancies.

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-40322, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40322, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-40322, filed 2/1/13, effective 7/1/13.]