(Effective until July 1, 2023)

WAC 51-11C-403231 Table C403.3.2(1)—Minimum efficiency requirements—Electrically operated unitary air conditioners and condensing units.

Table C403.3.2(1)A Minimum Efficiency Requirements—Electrically Operated Unitary Air Conditioners and Condensing Units

Equipment Type	Size Category	Heating Section Type	Subcategory or Rating Condition	Minimum Efficiency	Test Procedure ^A
Air conditioners, air cooled	< 65,000 Btu/h ^b	All	Split System	13.0 SEER	
			Single Package	14.0 SEER	
Through-the-wall	≤ 30,000 Btu/h ^b	All	Split system	12.0 SEER	AHRI 210/240
(air cooled)			Single Package	12.0 SEER	111111 210/210
Small duct high velocity, air cooled	< 65,000 Btu/h ^b	All	Split system	11.0 SEER	
	≥ 65,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	11.2 EER 12.9 IEER	
	and < 135,000 Btu/h	All other	Split System and Single Package	11.0 EER 12.7 IEER	
	≥ 135,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	11.0 EER 12.4 IEER	
Air conditioners,	< 240,000 Btu/h	All other	Split System and Single Package	10.8 EER 12.2 IEER	A LIDI 210/240
air cooled	≥ 240,000 Btu/h and < 760,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	10.0 EER 11.6 IEER	AHRI 210/240
		All other	Split System and Single Package	9.8 EER 11.4 IEER	
	≥ 760,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	9.7 EER 11.2 IEER	
		All other	Split System and Single Package	9.5 EER 11.6 IEER	
	< 65,000 Btu/h ^b	All	Split System and Single Package	12.1 EER 12.3 IEER	AHRI 210/240
	≥ 65,000 Btu/h and < 135,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	12.1 EER 13.9 IEER	
		All other	Split System and Single Package	11.9 EER 13.7 IEER	
Air conditioners, water cooled	≥ 135,000 Btu/h and < 240,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	12.5 EER 13.9 IEER	
		All other	Split System and Single Package	12.3 EER 13.7 IEER	AHRI 210/240
	≥ 240,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	12.4 EER 13.6 IEER	ARKI 210/240
	and < 760,000 Btu/h	All other	Split System and Single Package	12.2 EER 13.4 IEER	
	≥ 760,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	12.2 EER 13.5 IEER	
		All other	Split System and Single Package	12.0 EER 13.3 IEER	

Equipment Type	Size Category	Heating Section Type	Subcategory or Rating Condition	Minimum Efficiency	Test Procedure ^A
	< 65,000 Btu/h ^b	All	Split System and Single Package	12.1 EER 12.3 IEER	AHRI 210/240
	≥ 65,000 Btu/h and < 135,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	12.1 EER 12.3 IEER	
		All other	Split System and Single Package	11.9 EER 12.1 IEER	
	≥ 135,000 Btu/h and < 240,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	12.0 EER 12.2 IEER	
Air conditioners, evaporatively cooled		All other	Split System and Single Package	11.8 EER 12.0 IEER	AHRI 340/360
	≥ 240,000 Btu/h and < 760,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	11.9 EER 12.1 IEER	ATIKI 340/300
		All other	Split System and Single Package	11.7 EER 11.9 IEER	
	≥ 760,000 Btu/h	Electric Resistance (or None)	Split System and Single Package	11.7 EER 11.9 EER	
		All other	Split System and Single Package	11.5 EER 11.7 EER	
Condensing units, air cooled	≥ 135,000 Btu/h			10.5 EER 11.8 IEER	AHRI 365
Condensing units, water cooled	≥ 135,000 Btu/h			13.5 EER 14.0 IEER	
Condensing units, evaporatively cooled	≥ 135,000 Btu/h			13.5 EER 14.0 IEER	

For SI:

Table C403.3.2(1)B Minimum Efficiency Requirements—Electrically Operated Variable Refrigerant Flow Air Conditioners

Equipment Type	Size Category	Heating Section Type	Subcategory or Rating Condition	Minimum Efficiency	Test Procedure
VRF Air Conditioners, Air Cooled	< 65,000 Btu/h	All	VRF Multi-Split System	13.0 SEER	AHRI 1230
	≥ 65,000 Btu/h and < 135,000 Btu/h	Electric Resistance (or none)	VRF Multi-Split System	11.2 EER 15.5 IEER	
	≥ 135,000 Btu/h and < 240,000 Btu/h	Electric Resistance (or none)	VRF Multi-Split System	11.0 EER 14.9 IEER	
	≥ 240,000 Btu/h	Electric Resistance (or none)	VRF Multi-split System	10.0 EER 13.9 IEER	

Table C403.3.2(1)C Minimum Efficiency Requirements—Electrically Operated Variable Refrigerant Flow Air-to-Air and Applied Heat Pumps

Equipment Type	Size Category	Heating Section Type	Subcategory or Rating Condition	Minimum Efficiency	Test Procedure
VRF Air Cooled (cooling mode)	< 65,000 Btu/h	All	VRF Multi-Split System	13.0 SEER	AHRI 1230
	≥ 65,000 Btu/h and < 135,000 Btu/h	Electric Resistance (or none)	VRF Multi-Split System	11.0 EER 14.6 IEER	

¹ British thermal unit per hour = 0.2931 W. Chapter 12 of the referenced standard contains a complete specification of the referenced test procedure, including the reference year version of the

test procedure.
Single-phase, air-cooled air conditioners less than 65,000 Btu/h are regulated by NAECA. SEER values are those set by NAECA.

Equipment Type	Size Category	Heating Section Type	Subcategory or Rating Condition	Minimum Efficiency	Test Procedure
	≥ 65,000 Btu/h and < 135,000 Btu/h	Electric Resistance (or none)	VRF Multi-Split System with Heat Recovery	10.8 EER 14.4 IEER	
	≥ 135,000 Btu/h and < 240,000 Btu/h	Electric Resistance (or none)	VRF Multi-Split System	10.6 EER 13.9 IEER	
	≥ 135,000 Btu/h and < 240,000 Btu/h	Electric Resistance (or none)	VRF Multi-Split System with Heat Recovery	10.4 EER 13.7 IEER	
	≥ 240,000 Btu/h	Electric Resistance (or none)	VRF Multi-Split System	9.5 EER 12.7 IEER	
	≥ 240,000 Btu/h	Electric Resistance (or none)	VRF Multi-Split System with Heat Recovery	9.3 EER 12.5 IEER	
VRF Water Source (cooling mode)	< 65,000 Btu/h	All	VRF Multi-Split System 86°F entering water	12.0 EER 16.0 IEER	AHRI 1230
	< 65,000 Btu/h	All	VRF Multi-Split System with Heat Recovery 86°F entering water	11.8 EER 15.8 IEER	
	≥ 65,000 Btu/h and < 135,000 Btu/h	All	VRF Multi-Split System 86°F entering water	12.0 EER 16.0 IEER	
	≥ 65,000 Btu/h and < 135,000 Btu/h	All	VRF Multi-Split System with Heat Recovery 86°F entering water	11.8 EER 15.8 IEER	
	≥ 135,000 Btu/h and < 240,000 Btu/h	All	VRF Multi-Split System 86°F entering water	10.0 EER 14.0 IEER	
	≥ 135,000 Btu/h and < 240,000 Btu/h	All	VRF Multi-Split System with Heat Recovery 86°F entering water	9.8 EER 13.8 IEER	
	≥ 240,000 Btu/h	All	VRF Multi-Split System 86°F entering water	12.0 IEER	
	≥ 240,000 Btu/h	All	VRF Multi-Split System with Heat Recovery 86°F entering water	11.8 IEER	
VRF Groundwater Source (cooling mode)	< 135,000 Btu/h	All	VRF Multi-Split System 59°F entering water	16.2 EER	AHRI 1230
	< 135,000 Btu/h	All	VRF Multi-Split System with Heat Recovery 59°F entering water	16.0 EER	
	≥ 135,000 Btu/h	All	VRF Multi-Split System 59°F entering water	13.8 EER	
	≥ 135,000 Btu/h	All	VRF Multi-Split System with Heat Recovery 59°F entering water	13.6 EER	

Equipment Type	Size Category	Heating Section Type	Subcategory or Rating Condition	Minimum Efficiency	Test Procedure
VRF Ground Source (cooling mode)	< 135,000 Btu/h	All	VRF Multi-Split System 77°F entering water	13.4 EER	AHRI 1230
	< 135,000 Btu/h	All	VRF Multi-Split System with Heat Recovery 77°F entering water	13.2 EER	
	≥ 135,000 Btu/h	All	VRF Multi-Split System 77°F entering water	11.0 EER	
	≥ 135,000 Btu/h	All	VRF Multi-Split System with Heat Recovery 77°F entering water	10.8 EER	
VRF Air Cooled (heating mode)	< 65,000 Btu/h (cooling capacity)	_	VRF Multi-Split System	7.7 HSPF	AHRI 1230
	≥ 65,000 Btu/h and < 135,000 Btu/h (cooling capacity)	_	VRF Multi-Split System 47°F db/43°F wb outdoor air 17°F db/15°F wb outdoor air	3.3 COP 2.25 COP	
	≥ 135,000 Btu/h (cooling capacity)	_	VRF Multi-Split System 47°F db/43°F wb outdoor air 17°F db/15°F wb outdoor air	3.2 COP 2.05 COP	
VRF Water Source (heating mode)	<135,000 Btu/h (cooling capacity)	_	VRF Multi-Split System 68°F entering water	4.3 COP	AHRI 1230
, ,	≥ 135,000 Btu/h and < 240,000 Btu/h (cooling capacity)	_	VRF Multi-Split System 68°F entering water	4.0 COP	
	≥ 240,000 Btu/h (cooling capacity)	_	VRF Multi-Split System 68°F entering water	3.9 COP	
VRF Groundwater Source (heating mode)	< 135,000 Btu/h (cooling capacity)	_	VRF Multi-Split System 50°F entering water	3.6 COP	AHRI 1230
	≥ 135,000 Btu/h (cooling capacity)		VRF Multi-Split System 50°F entering water	3.3 COP	
VRF Ground Source (heating mode)	< 135,000 Btu/h (cooling capacity)		VRF Multi-Split System 32°F entering water	3.1 COP	AHRI 1230
	≥ 135,000 Btu/h (cooling capacity)		VRF Multi-Split System 32°F entering water	2.8 COP	

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-403231, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.045, 19.27A.160, and 19.27.074. WSR 17-10-062, § 51-11C-403231, filed 5/2/17, effective 6/2/17. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-403231, filed

1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-403231, filed 2/1/13, effective 7/1/13.]