

**WAC 51-11C-40336 Section C403.3.6—Ventilation for Group R-2 occupancy.**

**C403.3.6 Ventilation for Group R-2 occupancy.** For all Group R-2 dwelling and sleeping units, a balanced ventilation system with heat recovery system with minimum 60 percent sensible recovery effectiveness shall provide outdoor air directly to all habitable space. The ventilation system shall allow for the design flow rates to be tested and verified at each habitable space as part of the commissioning process in accordance with Section C408.2.2.

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-40336, filed 11/26/19, effective 7/1/20.]