## (Effective until July 1, 2023)

## WAC 51-50-07070 Section 707—Fire barriers.

707.4 Exterior walls. Where exterior walls serve as a part of a required fire-resistance-rated shaft or separation or enclosure for a stairway, ramp or exit passageway, such walls shall comply with the requirements of Section 705 for exterior walls and the fire-resistance-rated enclosure or separation requirements shall not apply.

Exterior walls required to be *fire-resistance-rated* in accordance with Section 1021 for exterior egress balconies, Section 1023.7 for interior exit stairways and ramps, Section 1024.8 for exit passageways and Section 1027.6 for exterior exit stairways and ramp.

707.5 Continuity. Fire barriers shall extend from the top of the foundation or floor/ceiling assembly below to the underside of the floor or roof sheathing, slab or deck above and shall be securely attached thereto. Such fire barriers shall be continuous through concealed space, such as the space above a suspended ceiling. Joints and voids at intersections shall comply with Sections 707.8 and 707.9.

- 1. Shaft enclosures shall be permitted to terminate at a top enclosure complying with Section 713.12.
  2. Interior exit stairway and ramp enclosures required by Section 1023 and exit access stairway and ramp enclosures required by Section 1019 shall be permitted to terminate at a top enclosure complying with Section 713.12.

  3. An exit passageway enclosure required by Section 1024.3 that does not extend to the underside of the roof sheathing, slab or deck
- above shall be enclosed at the top with construction of the same fire-resistance rating as required for the exit passageway.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-090, § 51-50-07070, filed 12/12/19, effective 7/1/20.]

# (Effective July 1, 2023)

## WAC 51-50-07070 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, filed 6/14/22, effective 7/1/23; WSR 51-50-07070, 20-01-090, 51-50-07070, filed 12/12/19, effective 7/1/20.]