

WAC 246-215-04315 Equipment—Ventilation hood systems, adequacy (FDA Food Code 4-301.14). Ventilation hood systems and devices must be sufficient in number and capacity to prevent grease or condensation from collecting on walls and ceilings.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-04315, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-04315, filed 1/17/13, effective 5/1/13.]