

WAC 246-215-05265 Location and placement—Conditioning device (FDA Food Code 5-204.13). A water filter, screen, and other water conditioning device installed on water lines must be located to facilitate disassembly for periodic servicing and cleaning.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-05265, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-05265, filed 1/17/13, effective 5/1/13.]