

**WAC 388-76-10810 Fire extinguishers.** (1) The adult family home must have an approved five pound 2A:10B-C rated fire extinguisher on each floor of the home.

(2) The home must ensure fire extinguishers are:

(a) Mounted or securely fastened in a stationary position at a minimum of four inches from the floor and a maximum of sixty inches from the floor;

(b) Inspected and serviced annually;

(c) In proper working order;

(d) Accessible at all times; and

(e) Not located behind a locked door.

[Statutory Authority: RCW 70.128.040 and 70.128.060. WSR 21-11-074, § 388-76-10810, filed 5/17/21, effective 8/1/21. Statutory Authority: RCW 70.128.040. WSR 08-09-028, § 388-76-10810, filed 4/8/08, effective 5/9/08. Statutory Authority: RCW 70.128.040 and chapters 70.128 and 74.34 RCW. WSR 07-21-080, § 388-76-10810, filed 10/16/07, effective 1/1/08.]