(Effective until March 15, 2024)

WAC 51-50-1004 Section 1004—Occupant load. Table 1004.5, Maximum Floor Area Allowances Per Occupant Table 1004.5

Maximum Floor Area Allowance Per Occupant

	OCCUPANT LOAD
FUNCTION OF SPACE	FACTOR ^a
Accessory storage areas, mechanical equipment room	300 gross
Agricultural building	300 gross
Aircraft hangars	500 gross
Airport terminal	
Baggage claim	20 gross
Baggage handling	300 gross
Concourse	100 gross
Waiting areas	15 gross
Assembly	
Gaming floors (keno, slots, etc.)	11 gross
Exhibit gallery and museum	30 net
Billiard table/game table area	50 gross
Assembly with fixed seats	See Section 1004.6
Assembly without fixed seats	
Concentrated (chairs only - not fixed)	7 net
Standing space	5 net
Unconcentrated (tables and chairs)	15 net
Bowling centers, allow 5 persons for each lane including 15 feet of runway, and for additional areas	7 net
Business areas	
Concentrated business use areas	150 gross (See Section 1004.8)
Courtrooms - Other than fixed seating	
areas	40 net
Day care	35 net
Dormitories	50 gross
Educational	
Classroom area	20 net
Shops and other vocational room areas	50 net
Exercise rooms	50 gross
Group H-5 fabrication and manufacturing areas	200 gross
Industrial areas	100 gross
Institutional areas	
Inpatient treatment areas	240 gross
Outpatient areas	100 gross
Sleeping areas	120 gross

FUNCTION OF SPACE	OCCUPANT LOAD FACTOR ^a
Kitchens, commercial	200 gross
Library	
Reading rooms	50 net
Stack area	100 gross
Locker rooms	50 gross
Mall buildings - Covered and open	See Section 402.8.2
Mercantile	60 gross
Storage, stock, shipping areas	300 gross
Group M art gallery	30 gross
Parking garages	200 gross
Residential	200 gross
Skating rinks, swimming pools	
Rink and pool	50 gross
Decks	15 gross
Stages and platforms	15 net
Warehouses	500 gross

For SI: 1 foot = 304.8 mm, 1 square foot = 0.0929 m^2 .

a Floor area in square feet per occupant.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-090, § 51-50-1004, filed 12/12/19, effective 7/1/20; WSR 19-02-038, § 51-50-1004, filed 12/26/18, effective 7/1/19; WSR 16-03-064, § 51-50-1004, filed 1/19/16, effective 7/1/16.]

(Effective March 15, 2024)

WAC 51-50-1004 Section 1004—Occupant load.

Table 1004.5 Maximum Floor Area Allowance Per Occupant

FUNCTION OF SPACE	OCCUPANT LOAD FACTOR ^a
Accessory storage areas, mechanical equipment room	300 gross
Agricultural building	300 gross
Aircraft hangars	500 gross
Airport terminal	
Baggage claim	20 gross
Baggage handling	300 gross
Concourse	100 gross
Waiting areas	15 gross
Assembly	
Gaming floors (keno, slots, etc.)	11 gross
Exhibit gallery and museum	30 net
Billiard table/game table area	50 gross

FUNCTION OF SPACE	OCCUPANT LOAD FACTOR ^a
Assembly with fixed seats	See Section
Assembly without fixed seats	1004.6
Concentrated (chairs only - not fixed)	7 net
Standing space	5 net
Unconcentrated (tables and chairs)	15 net
Bowling centers, allow 5 persons for each lane including 15 feet of runway, and for additional areas	7 net
Business areas	
Concentrated business use areas	150 gross (See Section 1004.8)
Courtrooms - Other than fixed seating areas	40 net
Day care	35 net
Dormitories	50 gross
Educational	
Classroom area	20 net
Shops and other vocational room areas	50 net
Exercise rooms	50 gross
Fixed guideway transit and passenger rail systems Platform Concourse/lobby	100 gross (See Section 3114)
Group H-5 fabrication and manufacturing areas	200 gross
Industrial areas	100 gross
Institutional areas	
Inpatient treatment areas	240 gross
Outpatient areas	100 gross
Sleeping areas	120 gross
Kitchens, commercial	200 gross
Library	
Reading rooms	50 net
Stack area	100 gross
Locker rooms	50 gross
Mall buildings - Covered and open	See Section 402.8.2
Mercantile	60 gross
Storage, stock, shipping areas	300 gross
Parking garages	200 gross
Residential	200 gross
Skating rinks, swimming pools	
Rink and pool	50 gross
Decks	15 gross
Stages and platforms	15 net
Warehouses	500 gross

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-1004, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-090, § 51-50-1004, filed 12/12/19, effective 7/1/20; WSR 19-02-038, § 51-50-1004, filed 12/26/18, effective 7/1/19; WSR 16-03-064, § 51-50-1004, filed 1/19/16, effective 7/1/16.]

(Effective March 16, 2024)

WAC 51-50-1004 Section 1004—Occupant load.

	Та	able 1	1004.5		
Maximum	Floor	Area	Allowance	Per	0c-
		cupa	ant		

	OCCUPANT LOAD
FUNCTION OF SPACE	FACTOR ^a
Accessory storage areas, mechanical equipment room	300 gross
Agricultural building	300 gross
Aircraft hangars	500 gross
Airport terminal	
Baggage claim	20 gross
Baggage handling	300 gross
Concourse	100 gross
Waiting areas	15 gross
Assembly	
Gaming floors (keno, slots, etc.)	11 gross
Exhibit gallery and museum	30 net
Billiard table/game table area	50 gross
Assembly with fixed seats	See Section 1004.6
Assembly without fixed seats	
Concentrated (chairs only - not fixed)	7 net
Standing space	5 net
Unconcentrated (tables and chairs)	15 net
Bowling centers, allow 5 persons for each lane including 15 feet of runway, and for additional areas	7 net
Business areas	
Concentrated business use areas	150 gross (See Section 1004.8)
Courtrooms - Other than fixed seating areas	40 net
Day care	35 net
Dormitories	50 gross
Educational	
Classroom area	20 net
Shops and other vocational room areas	50 net

FUNCTION OF SPACE	OCCUPANT LOAD FACTOR ^a
Exercise rooms	50 gross
Fixed guideway transit and passenger rail systems Platform Concourse/lobby	100 gross (See Section 3116)
Group H-5 fabrication and manufacturing areas	200 gross
Industrial areas	100 gross
Institutional areas	
Inpatient treatment areas	240 gross
Outpatient areas	100 gross
Sleeping areas	120 gross
Kitchens, commercial	200 gross
Library	
Reading rooms	50 net
Stack area	100 gross
Locker rooms	50 gross
Mall buildings - Covered and open	See Section 402.8.2
Mercantile	60 gross
Storage, stock, shipping areas	300 gross
Parking garages	200 gross
Residential	200 gross
Skating rinks, swimming pools	
Rink and pool	50 gross
Decks	15 gross
Stages and platforms	15 net
Warehouses	500 gross

a Floor area in square feet per occupant.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-102, § 51-50-1004, filed 11/15/23, effective 3/16/24; WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-1004, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-090, § 51-50-1004, filed 12/12/19, effective 7/1/20; WSR 19-02-038, § 51-50-1004, filed 12/26/18, effective 7/1/19; WSR 16-03-064, § 51-50-1004, filed 1/19/16, effective 7/1/16.]