

(Effective until March 15, 2024)

WAC 51-51-2105 Section M2105—Ground-source heat-pump system loop piping.

M2105.9 CPVC plastic pipe. Joints between CPVC plastic pipe or fittings shall be solvent-cemented in accordance with Section 605.2.2 of the state plumbing code. Threaded joints between fittings and CPVC plastic pipe shall be in accordance with Section M2105.9.1.

M2105.14 PVC plastic pipe. Joints between PVC plastic pipe or fittings shall be solvent-cemented in accordance with Section 605.12.2 of the state plumbing code. Threaded joints between fittings and PVC plastic pipe shall be in accordance with Section M2105.9.1.

M2105.18 Protection of potable water. Where ground-source heat-pump ground-loop systems have a connection to a potable water supply, the potable water system shall be protected from backflow in accordance with Section 603 of the state plumbing code.

M2105.19 Pipe penetrations. Openings for pipe penetrations in walls, floors and ceilings shall be larger than the penetrating pipe. Openings through concrete or masonry building elements shall be sleeved. The annular space surrounding pipe penetrations shall be protected in accordance with Section 312 of the state plumbing code.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-025, § 51-51-2105, filed 1/11/16, effective 7/1/16.]

(Effective March 15, 2024)

WAC 51-51-2105 Section M2105—Ground-source heat-pump system loop piping.

M2105.9 CPVC plastic pipe. Joints between CPVC plastic pipe or fittings shall be solvent-cemented in accordance with Section 605 of the state plumbing code. Threaded joints between fittings and CPVC plastic pipe shall be in accordance with Section M2105.9.1.

M2105.14 PVC plastic pipe. Joints between PVC plastic pipe or fittings shall be solvent-cemented in accordance with Section 605 of the state plumbing code. Threaded joints between fittings and PVC plastic pipe shall be in accordance with Section M2105.9.1.

M2105.18 Protection of potable water. Where ground-source heat-pump ground-loop systems have a connection to a potable water supply, the potable water system shall be protected from backflow in accordance with Section 603 of the state plumbing code.

M2105.19 Pipe penetrations. Openings for pipe penetrations in walls, floors and ceilings shall be larger than the penetrating pipe. Openings through concrete or masonry building elements shall be sleeved. The annular space surrounding pipe penetrations shall be protected in accordance with Section 312 of the state plumbing code.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-02-058, 23-12-104, and 23-20-024, § 51-51-2105, filed 1/3/23, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-03-025, § 51-51-2105, filed 1/11/16, effective 7/1/16.]