WAC 296-307-03935 Inspect and activate emergency washing facilities. (1) The employer must make sure all plumbed emergency washing facilities are inspected once a year to make sure they function correctly.

Note:

Inspections should include:

- 1. Examination of the piping.
- 2. Making sure that water is available at the appropriate temperature and quality.
- 3. Activation to check that the valves and other hardware work properly.
- 4. Checking the water flow rate.
- (2) The employer must make sure plumbed emergency eyewashes and hand-held drench hoses are activated weekly to check the proper functioning of the valves, hardware, and availability of water.
- (3) The employer must make sure all self-contained eyewash equipment and personal eyewash units are inspected and maintained according to manufacturer instructions.
- (a) Inspections to check proper operation must be done once a year.
- (b) Sealed personal eyewashes must be replaced after the manufacturer's expiration date.

Note:

Most manufacturers recommend replacing fluid in open self-contained eyewashes every six months. The period for sealed containers is typically two years.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-03935, filed 10/20/20, effective 11/20/20; WSR 03-10-068, § 296-307-03935, filed 5/6/03, effective 8/1/03.]