WAC 296-835-12025 Provide additional fire protection for large dip tanks. (1) You must provide at least one automatic fire extinquishing system or an automatic dip tank cover if the tank:

- (a) Holds one hundred fifty gallons or more of liquid; or
- (b) Has four square feet or more of liquid surface area.
- (2) You must make sure automatic fire extinguishing systems or automatic dip tank covers meet the requirements of Table 1.

Exemption: An automatic fire extinguishing system or an automatic dip tank cover is **not** required for a hardening or tempering tank that:

- 1. Holds less than five hundred gallons; or
- 2. Has less than twenty-five square feet of liquid surface area.

Table 1: Automatic Fire Protection System Requirements

IF YOU PROVIDE:	THEN YOU MUST:
An automatic fire extinguishing system	 Use extinguishing materials suitable for a fire fueled by the liquid in the tank Make sure the system protects the: Tanks Drain boards Stock over drain boards.
A dip tank cover	Make sure the cover is: Closed by approved automatic devices in the event of fire Able to be manually activated Kept closed when the tank is not being used Made of noncombustible material or tin-clad material with locked metal joints.

Reference: Automatic fire extinguishing systems have specific requirements. See:

- 1. WAC 296-24-622 for automatic dry chemical extinguishing system requirements.
- 2. WAC 296-24-623 for automatic carbon dioxide extinguishing system requirements.
- 3. WAC 296-24-627 for automatic water spray extinguishing system and automatic foam extinguishing system requirements.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 17-18-075, § 296-835-12025, filed 9/5/17, effective 10/6/17; WSR 07-03-163, § 296-835-12025, filed 1/24/07, effective 4/1/07. Statutory Authority: RCW 49.17.010, [49.17].040, and [49.17].050. WSR 02-15-102, § 296-835-12025, filed 7/17/02, effective 10/1/02.1