

WAC 296-870-30030 Disabling safety or electrical protective devices. (1) You must make sure no person renders any required safety devices or electrical protective devices inoperative unless necessary for tests, inspections, or maintenance.

(2) You must restore any disabled devices to normal operating condition immediately after the test, inspection or maintenance is completed.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050. WSR 15-23-086, § 296-870-30030, filed 11/17/15, effective 12/18/15. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 47.17.060. WSR 06-19-075, § 296-870-30030, filed 9/19/06, effective 1/1/07.]