WAC 388-97-2320 Utility service rooms on resident care units.

- (1) All nursing homes must:
- (a) Provide utility rooms designed, equipped, and maintained to ensure separation of clean and sterile supplies and equipment from those that are contaminated;
 - (b) Ensure that each clean utility room has:
 - (i) A work counter;
- (ii) A sink equipped with single use hand drying towels and soap for handwashing; and
 - (iii) Closed storage units for supplies and small equipment; and
 - (c) Ensure that each soiled utility room has:
- (i) A work counter and a sink large enough to totally submerge the items being cleaned and disinfected;
- (ii) Storage for cleaning supplies and other items, including equipment, to meet nursing home needs;
- (iii) Locked storage for cleaning agents, disinfectants and other caustic or toxic agents;
- (iv) Adequate space for waste containers, linen hampers, and other large equipment; and
 - (v) Adequate ventilation to remove odors and moisture.
 - (2) In new construction:
- (a) A resident room must not be more than ninety feet from a clean utility room and a soiled utility room;
- (b) The clean utility room and the soiled utility room must be separate rooms;
 - (c) Each soiled utility room must contain:
- (i) A double-compartment sink with inside dimensions of each compartment deep enough to totally submerge items being cleaned and disinfected;
- (ii) Sufficient, available work surface on each side of the sink to adequately process and dry equipment with a minimum of three feet of work surface on the clean side;
 - (iii) Drying/draining racks for wet equipment;
- (iv) Work counters, sinks, and other fixed equipment arranged to prevent intermingling of clean and contaminated items during the cleaning process; and
- (v) A siphon jet type clinic service sink or equivalent installed on the soiled side of the utility room away from the door.
- (d) The nursing home's space for waste containers, linen hampers, and other large equipment must not block work areas; and
- (e) The utility rooms must meet the ventilation requirements of Table 6 in WAC 388-97-4040.

[Statutory Authority: Chapters 18.51 and 74.42 RCW and 42 C.F.R. 489.52. WSR 08-20-062, § 388-97-2320, filed 9/24/08, effective 11/1/08.]