

**(Effective until July 1, 2020)**

**WAC 51-11C-40702 Section C407.2—Mandatory requirements.**

**C407.2 Mandatory requirements.** Compliance with this section requires that the criteria of Sections C402.5, C403.2, C404 and C405 be met.

The building permit application for projects utilizing this method shall include in one submittal all building and mechanical drawings and all information necessary to verify that the building envelope and mechanical design for the project corresponds with the annual energy analysis. If credit is proposed to be taken for lighting energy savings, then an electrical permit application shall also be submitted and approved prior to the issuance of the building permit. If credit is proposed to be taken for energy savings from other components, then the corresponding permit application (e.g., plumbing, boiler, etc.) shall also be submitted and approved prior to the building permit application. Otherwise, components of the project that would not be approved as part of a building permit application shall be modeled the same in both the proposed building and the *standard reference design* and shall comply with the requirements of this code.

[Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40702, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-40702, filed 2/1/13, effective 7/1/13.]

**(Effective July 1, 2020)**

**WAC 51-11C-40702 Section C407.2—Mandatory requirements.**

**C407.2 Mandatory requirements.** Compliance with this section requires compliance with those sections shown in Table C407.2.

The building permit application for projects utilizing this method shall include in one submittal all building and mechanical drawings and all information necessary to verify that the building envelope and mechanical design for the project corresponds with the annual energy analysis. If credit is proposed to be taken for lighting energy savings, then an electrical permit application shall also be submitted and approved prior to the issuance of the building permit. If credit is proposed to be taken for energy savings from other components, then the corresponding permit application (e.g., plumbing, boiler, etc.) shall also be submitted and approved prior to the building permit application. Otherwise, components of the project that would not be approved as part of a building permit application shall be modeled the same in both the proposed building and the *standard reference design* and shall comply with the requirements of this code.

**Table C407.2  
Mandatory Compliance Measures for  
Total Building Performance Method**

Section	Title	Comments
<b>Envelope</b>		
C402.5	Air leakage	
<b>Mechanical</b>		
C403.1.2	Calculation of heating and cooling loads	

<b>Section</b>	<b>Title</b>	<b>Comments</b>
C403.1.3	Data centers	
C403.2	System design	
C403.3.1	Equipment and system sizing	
C403.3.2	HVAC equipment performance requirements	
C403.3.6	Ventilation for Group R occupancy	
C403.4	HVAC system controls	
C403.4.1	Thermostatic controls	Except for C403.4.1.4
C403.4.2	Off-hour controls	Except for Group R
C403.4.7	Combustion heating equipment controls	
C403.4.8	Group R-1 hotel/motel guestrooms	See Section C403.7.6
C403.4.9	Group R-2 and R-3 dwelling units	
C403.4.10	Group R-2 sleeping units	
C403.4.11	Direct digital control systems	
C403.5.5	Economizer fault detection and diagnostics (FDD)	
C403.7	Ventilation and exhaust systems	Except for C403.7.6
C403.8	Fan and fan controls	
C403.9.1.1	Variable flow controls	For cooling tower fans $\geq 7.5$ hp
C403.9.1.2	Limitation on centrifugal fan cooling towers	For open cooling towers
C403.10	Construction of HVAC elements	
C403.11	Mechanical systems located outside of the building thermal envelope	
<b>Service Water Heating</b>		
C404	Service water heating	
<b>Lighting and Electrical</b>		
C405.1	General	
C405.2	Lighting controls	
C405.3	Exit signs	
C405.4	Interior lighting power	
C405.5	Exterior building lighting power	

<b>Section</b>	<b>Title</b>	<b>Comments</b>
C405.6	Electrical transformers	
C405.7	Dwelling unit energy consumption	
C405.8	Electric motor efficiency	
C405.9	Vertical and horizontal transportation	
C405.10	Controlled receptacles	
C405.11	Voltage drop in feeders	
<b>Other Requirements</b>		
C407	Total building performance	
C408	System commissioning	
C409	Energy metering	
C410	Refrigeration requirements	
C411	Solar readiness	

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-40702, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40702, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-40702, filed 2/1/13, effective 7/1/13.]