

WAC 246-215-05220 Design, construction and installation—Back-flow prevention device, design standard (2009 FDA Food Code 5-202.14). A backflow or backsiphonage prevention device installed on a water supply system must meet American Society of Sanitary Engineering (A.S.S.E.) standards for construction, installation, maintenance, inspection, and testing for that specific application and type of device.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05220, filed 1/17/13, effective 5/1/13.]