

**WAC 296-835-13015 Meet specific requirements if you use a flow coating process.** (1) You must make sure all piping is substantial and rigidly supported.

(2) You must make sure the paint is supplied by a:

(a) Gravity tank that does not hold more than ten gallons (38 L);

or

(b) Direct low-pressure pumping system.

(3) You must have an approved heat-actuated device that shuts down the pumping system if there is a fire.

**Note:** The area of the sump, and any areas on which paint flows, should be included in the area of dip tank.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 17-18-075, § 296-835-13015, filed 9/5/17, effective 10/6/17. Statutory Authority: RCW 49.17.010, [49.17].040, and [49.17].050. WSR 02-15-102, § 296-835-13015, filed 7/17/02, effective 10/1/02.]