

WAC 296-874-20006 Maintain structural integrity when intermixing scaffold components. (1) You must make sure intermixed scaffold components:

- (a) Fit together without force; and
- (b) Maintain the scaffold's structural integrity.

(2) You must make sure a qualified person determines that modifying components in order to intermix them will result in a structurally sound scaffold.

(3) You must make sure scaffold components made of different metals are not used together.

EXEMPTION: Different types of metals may be used together if a competent person determines that galvanic action will not reduce the strength of any component to less than the minimum strength required.

Reference: The minimum strength requirements are found in the following sections:
1. Suspended scaffolds, WAC 296-874-30002;
2. Supported scaffolds, WAC 296-874-40002.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050. WSR 15-23-086, § 296-874-20006, filed 11/17/15, effective 12/18/15. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060. WSR 05-01-054, § 296-874-20006, filed 12/7/04, effective 3/1/05.]