

**WAC 388-107-1020 General.** In areas accessed by residents, the facility must have:

(1) Electrical receptacles that are tamper-resistant or equipped with ground fault circuit interrupters.

(2) Lights designed to prevent unauthorized access and tampering.

[Statutory Authority: Chapter 70.97 RCW. WSR 14-19-071, § 388-107-1020, filed 9/12/14, effective 10/13/14.]