

(Effective until July 1, 2020)

WAC 51-11C-303131 Table C303.1.3(1)—Default glazed fenestration U-factors.

**Table C303.1.3(1)
Default Glazed Fenestration U-Factors**

FRAME TYPE	SINGLE PANE	DOUBLE PANE	SKY-LIGHT
Metal	1.20	0.80	See Table C303.1.3(4)
Metal with Thermal Break	1.10	0.65	
Nonmetal or Metal Clad	0.95	0.55	
Glazed Block	0.60		

[Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-303131, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-303131, filed 2/1/13, effective 7/1/13.]

(Effective July 1, 2020)

WAC 51-11C-303131 Table C303.1.3(1)—Default glazed window, glass door and skylight U-factors.

**Table C303.1.3(1)
Default Glazed Window, Glass Door
and Skylight U-Factors**

FRAME TYPE	Window and Glass Door		SKY-LIGHT
	SINGLE PANE	DOUBLE PANE	
Metal	1.20	0.80	See Table C303.1.3(4)
Metal with Thermal Break	1.10	0.65	
Nonmetal or Metal Clad	0.95	0.55	
Glazed Block	0.60		

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-303131, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-303131, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-303131, filed 2/1/13, effective 7/1/13.]