

(Effective until July 1, 2020)

WAC 51-11C-402141 Table C402.1.4—Opaque thermal envelope requirements, U-factor method.

Table C402.1.4
Opaque Thermal Envelope Requirements^{a, f}

CLIMATE ZONE	5 AND MARINE 4	
	All Other	Group R
Roofs		
Insulation entirely above deck	U-0.027	U-0.027
Metal buildings	U-0.031	U-0.031
Attic and other	U-0.021	U-0.021
Joist or single rafter	U-0.027	U-0.027
Walls, Above Grade		
Mass	U-0.104 ^d	U-0.078
Mass transfer deck slab edge	U-0.20	U-0.20
Metal building	U-0.052	U-0.052
Steel framed	U-0.055	U-0.055
Wood framed and other	U-0.054	U-0.054
Walls, Below Grade		
Below-grade wall ^b	Same as above grade	Same as above grade
Floors		
Mass ^e	U-0.031	U-0.031
Joist/framing	U-0.029	U-0.029
Slab-on-Grade Floors		
Unheated slabs	F-0.54	F-0.54
Heated slabs ^c	F-0.55	F-0.55
Opaque Doors		
Swinging	U-0.37	U-0.37
Nonswinging	U-0.34	U-0.34

- ^a Use of opaque assembly *U*-factors, *C*-factors, and *F*-factors from Appendix A is required unless otherwise allowed by Section C402.1.4.
- ^b Where heated slabs are below grade, they shall comply with the *F*-factor requirements for heated slabs.
- ^c Heated slab *F*-factors shall be determined specifically for heated slabs. Unheated slab factors shall not be used.
- ^d Exception: Integral insulated concrete block walls complying with ASTM C90 with all cores filled and meeting both of the following:
 1. At least 50 percent of cores must be filled with vermiculite or equivalent fill insulation; and
 2. The building thermal envelope encloses one or more of the following uses: Warehouse (storage and retail), gymnasium, auditorium, church chapel, arena, kennel, manufacturing plant, indoor swimming pool, pump station, water and waste water treatment facility, storage facility, storage area, motor vehicle service facility. Where additional uses not listed (such as office, retail, etc.) are contained within the building, the exterior walls that enclose these areas may not utilize this exception and must comply with the appropriate mass wall R-value from Table C402.1.3/U-factor from Table C402.1.4.
- ^e "Mass floors" shall include floors weighing not less than:
 1. 35 pounds per square foot of floor surface area; or
 2. 25 pounds per square foot of floor surface area where the material weight is not more than 120 pounds per cubic foot.

^f Opaque assembly *U*-factors based on designs tested in accordance with ASTM C1363 shall be permitted. The *R*-value of continuous insulation shall be permitted to be added or subtracted from the original test design.

[Statutory Authority: RCW 19.27A.025, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-24-070, § 51-11C-402141, filed 12/6/16, effective 5/1/17. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-402141, filed 1/19/16, effective 7/1/16.]

(Effective July 1, 2020)

WAC 51-11C-402141 Table C402.1.4—Opaque thermal envelope requirements, *U*-factor method.

**Table C402.1.4
Opaque Thermal Envelope Requirements^{a, f}**

CLIMATE ZONE	5 AND MARINE 4	
	All Other	Group R
Roofs		
Insulation entirely above deck	U-0.027	U-0.027
Metal buildings	U-0.031	U-0.031
Attic and other	U-0.021	U-0.021
Joist or single rafter	U-0.027	U-0.027
Walls, Above Grade		
Mass ^g	U-0.104 ^d	U-0.078
Mass transfer deck slab edge	U-0.20	U-0.20
Metal building	U-0.052	U-0.052
Steel framed	U-0.055	U-0.055
Wood framed and other	U-0.054	U-0.051
Walls, Below Grade		
Below-grade wall ^{b, g}	Same as above grade	Same as above grade
Floors		
Mass ^e	U-0.031	U-0.031
Joist/framing	U-0.029	U-0.029
Slab-on-Grade Floors		
Unheated slabs	F-0.54	F-0.54
Heated slabs ^c	F-0.55	F-0.55
Opaque Doors		
Swinging door	U-0.37	U-0.37
Nonswinging door	U-0.34	U-0.34
Garage door <14% glazing	U-0.31	U-0.31

^a Use of opaque assembly *U*-factors, *C*-factors, and *F*-factors from Appendix A is required unless otherwise allowed by Section C402.1.4.
^b Where heated slabs are below grade, they shall comply with the *F*-factor requirements for heated slabs.

- c Heated slab *F*-factors shall be determined specifically for heated slabs. Unheated slab factors shall not be used.
- d Exception: Integral insulated concrete block walls complying with ASTM C90 with all cores filled and meeting both of the following:
 1. At least 50 percent of cores must be filled with vermiculite or equivalent fill insulation; and
 2. The building thermal envelope encloses one or more of the following uses: Warehouse (storage and retail), gymnasium, auditorium, church chapel, arena, kennel, manufacturing plant, indoor swimming pool, pump station, water and waste water treatment facility, storage facility, storage area, motor vehicle service facility. Where additional uses not listed (such as office, retail, etc.) are contained within the building, the exterior walls that enclose these areas may not utilize this exception and must comply with the appropriate mass wall *R*-value from Table C402.1.3/*U*-factor from Table C402.1.4.
- e "Mass floors" shall include floors weighing not less than:
 1. 35 pounds per square foot of floor surface area; or
 2. 25 pounds per square foot of floor surface area where the material weight is not more than 120 pounds per cubic foot.
- f Opaque assembly *U*-factors based on designs tested in accordance with ASTM C1363 shall be permitted. The *R*-value of continuous insulation shall be permitted to be added or subtracted from the original test design.
- g Peripheral edges of intermediate concrete floors are included in the above-grade mass wall category and therefore must be insulated as above-grade mass walls unless they meet the definition of Mass Transfer Deck Slab Edge. The area of the peripheral edges of concrete floors shall be defined as the thickness of the slab multiplied by the perimeter length of the edge condition. See Table A103.3.7.2 for typical default *U*-factors for above-grade slab edges and footnote ^c for typical conditions of above-grade slab edges.

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-402141, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-24-070, § 51-11C-402141, filed 12/6/16, effective 5/1/17. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-402141, filed 1/19/16, effective 7/1/16.]