

(Effective until July 1, 2020)

WAC 51-11R-40213 Table R402.1.3—Equivalent U-factors.

**TABLE R402.1.3
EQUIVALENT U-FACTORS^a**

Climate Zone	Fenestration U-Factor	Skylight U-Factor	Ceiling U-Factor	Frame Wall U-Factor	Mass Wall U-Factor^b	Floor U-Factor	Below-Grade Wall U-Factor
5 and Marine 4	0.30	0.50	0.026	0.056	0.056	0.029	0.042

^a Nonfenestration U-factors shall be obtained from measurement, calculation or an approved source or as specified in Section R402.1.3.

^b Reserved.

^c Reserved.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-40213, filed 1/6/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.045 and chapters 19.27 and 34.05 RCW. WSR 13-04-055, § 51-11R-40213, filed 2/1/13, effective 7/1/13.]

(Effective July 1, 2020)

WAC 51-11R-40213 Table R402.1.3—Equivalent U-factors.

**TABLE R402.1.3
EQUIVALENT U-FACTORS^a**

Climate Zone 5 and Marine 4	
Fenestration U-Factor	0.30
Skylight U-Factor	0.50
Ceiling U-Factor	0.026
Above-Grade Wall U-Factor	0.056
Floor U-Factor	0.029
Slab on Grade F-Factor	0.54
Below Grade 2' Depth	
Wall U-Factor	0.042
Slab F-Factor	0.59
Below Grade 3.5' Depth	
Wall U-Factor	0.040
Slab F-Factor	0.56
Below Grade 7' Depth	
Wall U-Factor	0.035
Slab F-Factor	0.50

^a U-factors or F-factors shall be obtained from measurement, calculation or an approved source or as specified in Section R402.1.5.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160 and chapter 19.27 RCW. WSR 20-01-047, § 51-11R-40213, filed 12/9/19, effective 7/1/20. Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-40213, filed 1/6/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.045 and chapters 19.27 and 34.05 RCW. WSR 13-04-055, § 51-11R-40213, filed 2/1/13, effective 7/1/13.]