

(Effective until July 1, 2020)

WAC 51-11R-40250 Section R402.5—Maximum fenestration U-factor and SHGC.

R402.5 Maximum fenestration U-factor (Mandatory). The area-weighted average maximum fenestration U-factor permitted using tradeoffs from Section R402.1.4 or R405 shall be 0.48 for vertical fenestration, and 0.75 for skylights.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-40250, filed 1/6/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.045 and chapters 19.27 and 34.05 RCW. WSR 13-04-055, § 51-11R-40250, filed 2/1/13, effective 7/1/13.]

(Effective July 1, 2020)

WAC 51-11R-40250 Section R402.5—Maximum fenestration U-factor and SHGC.

R402.5 Maximum fenestration U-factor. The area-weighted average maximum fenestration U-factor permitted using tradeoffs from Section R402.1.4 or R405 shall be 0.48 for vertical fenestration, and 0.75 for skylights.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160 and chapter 19.27 RCW. WSR 20-01-047, § 51-11R-40250, filed 12/9/19, effective 7/1/20. Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-40250, filed 1/6/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.045 and chapters 19.27 and 34.05 RCW. WSR 13-04-055, § 51-11R-40250, filed 2/1/13, effective 7/1/13.]