

(Effective July 1, 2020)

WAC 51-50-0704 Section 704—Fire-resistance rating of structural members.

704.6.1 Secondary (nonstructural) attachments to structural members.

Where primary and secondary structural steel members require fire protection, secondary (nonstructural) tubular steel attachments to those structural members shall be protected with the same fire resistive rating as required for the structural member. The protection shall extend from the structural member a distance of not less than 12 inches. An open tubular attachment shall be filled with an equivalent fire protection method for a distance of 12-inch length from the structural member, or the entire length of the open tube, whichever is less.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-090, § 51-50-0704, filed 12/12/19, effective 7/1/20.]