

(Effective until July 1, 2020)

WAC 51-50-1028 Section 1028—Exit discharge.

1028.4.1 Width or capacity. The required capacity of egress courts shall be determined as specified in Section 1005.1, but the minimum width shall be not less than 44 inches (1,118 mm), except as specified herein. Egress courts serving Group R-3 and U occupancies shall be not less than 36 inches (914 mm) in width. The required capacity and width of egress courts shall be unobstructed to a height of 7 feet (2,134 mm).

EXCEPTION: Encroachments complying with Section 1005.7.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-064, § 51-50-1028, filed 1/19/16, effective 7/1/16.]

(Effective July 1, 2020)

WAC 51-50-1028 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-090, § 51-50-1028, filed 12/12/19, effective 7/1/20; WSR 16-03-064, § 51-50-1028, filed 1/19/16, effective 7/1/16.]