

WAC 212-10-035 Number of smoke detection devices. (1) At least one smoke detection device shall be installed to protect the sleeping area within each dwelling unit. A sleeping area is defined as the area or areas of the dwelling unit in which the bedrooms (or sleeping rooms) are located. Where bedrooms or rooms ordinarily used for sleeping are separated by other-use areas (such as kitchens or living rooms but not bathrooms or closets), or are located on different stories or floor levels, they shall be considered as separate sleeping areas for the purposes of these rules.

(2) Dwelling units with more than one sleeping area shall require the installation of additional smoke detection devices to protect each sleeping area.

[Statutory Authority: RCW 48.48.140. WSR 81-04-058 (Order FM 81-2), § 212-10-035, filed 2/4/81.]