

**WAC 212-44-100 Equipment maintenance.** Every required automatic sprinkler system, fire detection and alarm system, exit lighting, fire door and other item of equipment required by this regulation or the applicable building and/or fire code shall be continuously maintained in proper operating condition. Equipment shall be tested or operated in accordance with manufacturer's recommendation and/or at sufficient intervals to assure reliability. Records of all tests and inspections shall be maintained for review. Tests and inspections shall be under the supervision of a responsible person.

[Order FM-77-3, § 212-44-100, filed 12/8/77.]