

WAC 296-96-24273 Electrical requirements. (1) All wiring shall conform to the NEC in effect at the time of installation or major alteration.

(2) If a driving machine is mounted on the conveyance chassis, the electrical connections between the conveyance and the power source shall be able to stop power if a traveling cable parts.

(3) All electrical connections between the conveyance chassis and the stationary connections shall be insulated flexible conductors conforming to the applicable articles of the NEC relating to elevators, dumbwaiters, escalators, moving walks, wheelchair lifts, and stairway chair lifts.

(4) An elevator mechanic employed by an elevator contractor may perform electrical work starting from the load side inside the controller.

[Statutory Authority: Chapter 70.87 RCW. WSR 18-18-070, § 296-96-24273, filed 8/31/18, effective 10/1/18.]