

WAC 296-96-24428 Guarding of floor landings. Expanded metal, sheet metal or wooden guards shall be installed on each floor landing to prevent people from placing their hands in areas where step-rollers operate. These guards shall be installed on each exposed side of the lift and extend from the floor to a height of 84 in.

[Statutory Authority: Chapter 70.87 RCW. WSR 18-18-070, § 296-96-24428, filed 8/31/18, effective 10/1/18.]