

WAC 296-307-34509 What are the installation and restoration requirements for employee alarm systems? (1) You must ensure that all systems installed to comply with this standard are approved. Steam whistles, air horns, strobe lights or similar lighting devices, or tactile devices meeting the requirements of this section must also be approved.

(2) After each test or alarm, you must ensure that all employee alarm systems are restored to normal operating condition as soon as possible. You must ensure that you have spare alarm components available in sufficient quantities and locations for prompt restoration of the system.

[WSR 97-09-013, recodified as § 296-307-34509, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-34509, filed 10/31/96, effective 12/1/96.]