

**WAC 296-307-42011 What is the maximum capacity allowed for non-DOT containers?** A non-DOT storage container must have a maximum 90,000 gallons water capacity.

[WSR 97-09-013, recodified as § 296-307-42011, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-42011, filed 10/31/96, effective 12/1/96.]