

WAC 468-34-280 Overhead power and communication lines—Type of construction. Longitudinal installations on the right of way should be single pole construction. Joint use single pole construction is generally desirable and should be used whenever feasible.

[Statutory Authority: 1977 ex.s. c 151. WSR 79-01-033 (DOT Order 10 and Comm. Order 1, Resolution No. 13), § 468-34-280, filed 12/20/78. Formerly WAC 252-04-245.]