

WAC 51-54A-0105 Permits.

SECTION 105 SCOPE AND GENERAL REQUIREMENTS

105.6.4 Carbon dioxide systems. An operational permit is required for carbon dioxide systems having more than 100 pounds of carbon dioxide.

105.6.4.9 Marijuana extraction systems. An operational permit is required to use a marijuana/cannabis extraction system regulated under WAC 314-55-104.

105.6.30 Mobile food preparation vehicles. A permit is required for mobile preparation vehicles equipped with appliances that produce smoke or grease-laden vapors or utilize LP-gas systems or CNG systems.

105.7.19 Marijuana extraction systems. A construction permit is required to install a marijuana/cannabis extraction system regulated under WAC 314-55-104.

105.7.20 Underground supply piping for automatic sprinkler system. A construction permit is required for the installation of the portion of the underground water supply piping, public or private, supplying a water-based fire protection system. The permit shall apply to all underground piping and appurtenances downstream of the first control valve on the lateral piping or service line from the distribution main to one foot above finished floor of the facility with the fire protection system. Maintenance performed in accordance with this code is not considered to be a modification and does not require a permit.

EXCEPTIONS: 1. When the underground piping is installed by the aboveground piping contractor.
 2. Underground piping serves a fire protection system installed in accordance with NFPA 13D.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-0105, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0105, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0105, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0105, filed 2/1/13, effective 7/1/13.]