

**WAC 110-305-2725 Portable heaters and generators.** (1) The licensee must not use or allow the use of portable heaters or fuel-powered generators in any area inside of licensed space during operating hours.

(2) When a portable fuel-powered generator is in use:

(a) The generator must be placed at least fifteen feet from buildings, windows, doors, ventilation intakes, or other places where exhaust fumes may be vented into the licensed space; and

(b) Appliances must be plugged directly into the generator or to a heavy duty outdoor-rated extension cord that is plugged into the generator.

[WSR 18-14-078, recodified as § 110-305-2725, filed 6/29/18, effective 7/1/18. Statutory Authority: Chapter 43.215 RCW. WSR 12-23-057, § 170-297-2725, filed 11/19/12, effective 12/20/12.]