

(Effective until March 1, 2022.)

WAC 246-215-05325 Design and construction—Inlet and outlet, sloped to drain (2009 FDA Food Code 5-302.15). (1) A water tank and its inlet and outlet must be sloped to drain.

(2) A water tank inlet must be positioned so that it is protected from contaminants such as waste discharge, road dust, oil or grease.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05325, filed 1/17/13, effective 5/1/13.]

(Effective March 1, 2022.)

WAC 246-215-05325 Design and construction—Inlet and outlet, sloped to drain (FDA Food Code 5-302.15). (1) A water tank and its inlet and outlet must be sloped to drain.

(2) A water tank inlet must be positioned so that it is protected from contaminants such as waste discharge, road dust, oil or grease.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-05325, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-05325, filed 1/17/13, effective 5/1/13.]