

WAC 388-76-10810 Fire extinguishers. (1) The adult family home must have an approved five pound 2A:10B-C rated fire extinguisher on each floor of the home.

(2) The home must ensure the fire extinguishers are:

(a) Installed according to manufacturer recommendations;

(b) Inspected and serviced annually;

(c) In proper working order; and

(d) Readily available for use at all times.

(3) If required by the local fire authority, the home must provide different fire extinguishers in place of the fire extinguishers required in subsection (1) of this section.

[Statutory Authority: RCW 70.128.040. WSR 08-09-028, § 388-76-10810, filed 4/8/08, effective 5/9/08. Statutory Authority: RCW 70.128.040 and chapters 70.128 and 74.34 RCW. WSR 07-21-080, § 388-76-10810, filed 10/16/07, effective 1/1/08.]