

**WAC 388-97-3460 Preinstallation submissions for new construction.** The department of health, construction review, must receive and approve preinstallation submissions prior to installation. Preinstallation submissions may include any or all of the following:

(1) Stamped shop drawings, hydraulic calculations, and equipment information sheets for fire sprinkler system(s);

(2) Shop drawings, battery calculations, and equipment information sheets for fire detection and alarm systems;

(3) Shop drawings and equipment information sheets for a kitchen hood and duct automatic fire extinguishing system;

(4) Drawings and equipment information sheets for special egress control devices; and

(5) Drawings and/or a finish schedule denoting areas to be carpeted with:

(a) A coding system identifying type of carpet in each area;

(b) A copy the manufacturer's specifications for each type of carpet; and

(c) A copy of a testing laboratory report of the radiant panel and smoke density tests for each type of carpet.

[Statutory Authority: Chapters 18.51 and 74.42 RCW and 42 C.F.R. 489.52. WSR 08-20-062, § 388-97-3460, filed 9/24/08, effective 11/1/08.]