

Chapter 51-54A WAC
STATE BUILDING CODE ADOPTION AND AMENDMENT OF THE 2018 EDITION OF THE
INTERNATIONAL FIRE CODE

Last Update: 6/9/21

WAC

| | |
|-------------|---|
| 51-54A-001 | Authority. |
| 51-54A-002 | Purpose. |
| 51-54A-003 | International Fire Code. |
| 51-54A-007 | Exceptions. |
| 51-54A-008 | Implementation. |
| 51-54A-0101 | Section 101. |
| 51-54A-0105 | Permits. |
| 51-54A-0202 | General definitions. |
| 51-54A-0307 | Open burning, recreational fires and portable outdoor fireplaces. |
| 51-54A-0308 | Open flames. |
| 51-54A-0314 | Indoor displays. |
| 51-54A-0315 | General storage. |
| 51-54A-0319 | Mobile food preparation vehicles. |
| 51-54A-0401 | General. |
| 51-54A-0402 | Definitions. |
| 51-54A-0403 | Emergency preparedness requirements. |
| 51-54A-0404 | Fire safety and evacuation plans. |
| 51-54A-0405 | Reserved. |
| 51-54A-0406 | Employee training and response procedures. |
| 51-54A-0408 | Reserved. |
| 51-54A-0503 | Fire apparatus access roads. |
| 51-54A-0507 | Fire protection water supplies. |
| 51-54A-0508 | Fire command center. |
| 51-54A-0510 | Emergency responder radio coverage. |
| 51-54A-0605 | Reserved. |
| 51-54A-0607 | Section 607—Commercial kitchen hoods. |
| 51-54A-0609 | Reserved. |
| 51-54A-0701 | General. |
| 51-54A-0806 | Decorative vegetation in new and existing buildings. |
| 51-54A-0901 | General. |
| 51-54A-0903 | Automatic sprinkler systems. |
| 51-54A-0904 | Alternative automatic fire-extinguishing systems. |
| 51-54A-0907 | Fire alarm and detection systems. |
| 51-54A-0908 | Reserved. |
| 51-54A-0909 | Reserved. |
| 51-54A-0915 | Carbon monoxide detection. |
| 51-54A-0916 | Reserved. |
| 51-54A-0918 | Alerting systems. |
| 51-54A-1007 | Reserved. |
| 51-54A-1008 | Reserved. |
| 51-54A-1009 | Accessible means of egress. |
| 51-54A-1010 | Doors, gates and turnstiles. |
| 51-54A-1011 | Stairways. |
| 51-54A-1012 | Ramps. |
| 51-54A-1018 | Reserved. |
| 51-54A-1020 | Corridors. |
| 51-54A-1021 | Reserved. |
| 51-54A-1028 | Reserved. |
| 51-54A-1030 | Reserved. |
| 51-54A-1103 | Fire safety requirements for existing buildings. |
| 51-54A-1104 | Means of egress for existing buildings. |
| 51-54A-1105 | Construction requirements for existing Group I-2. |
| 51-54A-1204 | Section 1204—Solar photovoltaic power systems. |
| 51-54A-3103 | Temporary tents and membrane structures. |
| 51-54A-3304 | Precautions against fire. |
| 51-54A-3308 | Owner's responsibility for fire protection. |
| 51-54A-3601 | Marinas—Scope. |
| 51-54A-3602 | Definitions. |
| 51-54A-3604 | Fire protection equipment. |
| 51-54A-3800 | Reserved. |
| 51-54A-3900 | Marijuana processing or extraction facilities. |
| 51-54A-3904 | Systems and equipment. |
| 51-54A-4000 | Fixed guideway transit and passenger rail systems. |
| 51-54A-5003 | General requirements. |
| 51-54A-5306 | Medical gas systems. |
| 51-54A-5307 | Reserved. |
| 51-54A-5601 | General. |
| 51-54A-5704 | Storage. |
| 51-54A-5706 | Special operations. |
| 51-54A-5707 | Section 5705—On-demand mobile fueling operations. |
| 51-54A-6108 | Fire protection. |
| 51-54A-8000 | Referenced standards. |
| 51-54A-8100 | Reserved. |
| 51-54A-8200 | International Wildland-Urban Interface Code. |

WAC 51-54A-001 Authority. These rules are adopted under the authority of chapter 19.27 RCW.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-001, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-002 Purpose. The purpose of these rules is to implement the provisions of chapter 19.27 RCW, which provides that the State Building Code Council shall maintain the State Building Code in a status which is consistent with the purpose as set forth in RCW 19.27.020. In maintaining the codes the council shall regularly review updated versions of the codes adopted under the act, and other pertinent information, and shall amend the codes as deemed appropriate by the council.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-002, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-003 International Fire Code. The 2018 edition of the International Fire Code, published by the International Code Council is hereby adopted by reference with the following additions, deletions, and exceptions.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-003, filed 11/27/19, effective 7/1/20; WSR 16-05-065, § 51-54A-003, filed 2/12/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-003, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-007 Exceptions. The exceptions and amendments to the International Fire Code contained in the provisions of chapter 19.27 RCW shall apply in case of conflict with any of the provisions of these rules.

Codes referenced which are not adopted through RCW 19.27.031 or chapter 19.27A RCW shall not apply unless specifically adopted by the authority having jurisdiction. The 2018 International Wildland Urban Interface Code is included in this code as Section 8200 with amendments found in Appendix Chapter N.

The provisions of this code do not apply to temporary growing structures used solely for the commercial production of horticultural plants including ornamental plants, flowers, vegetables, and fruits. "Temporary growing structure" means a structure that has the sides and roof covered with polyethylene, polyvinyl, or similar flexible synthetic material and is used to provide plants with either frost protection or increased heat retention. A temporary growing structure is not considered a building for purposes of this code.

The provisions of this code do not apply to the construction, alteration, or repair of temporary worker housing except as provided by rule adopted under chapter 70.114A RCW or chapter 37, Laws of 1998 (2SSB 6168). "Temporary worker housing" means a place, area, or piece of land where sleeping places or housing sites are provided by an employer for his or her employees or by another person, including a tem-

porary worker housing operator, who is providing such accommodations for employees, for temporary, seasonal occupancy, and includes "labor camps" under RCW 70.54.110.

The manufacture, storage, handling, sale and use of fireworks shall be governed by chapter 70.77 RCW and by chapter 212-17 WAC and local ordinances consistent with chapter 212-17 WAC.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-007, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-007, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-05-065, § 51-54A-007, filed 2/12/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-007, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-008 Implementation. The *International Fire Code* adopted by chapter 51-54A WAC shall become effective in all counties and cities of this state on February 1, 2021.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-11-066, § 51-54A-008, filed 5/14/21, effective 6/14/21; WSR 19-24-058, § 51-54A-008, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-008, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-008, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0101 Section 101.

Reserved.

[Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0101, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0101, filed 12/18/19, effective 7/1/20; WSR 16-05-065, § 51-54A-0101, filed 2/12/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0101, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0105 Permits.

SECTION 105 SCOPE AND GENERAL REQUIREMENTS

105.6.30 Mobile food preparation vehicles. A permit is required for mobile preparation vehicles equipped with appliances that produce smoke or grease-laden vapors or utilize LP-gas systems or CNG systems.

105.7.26 Underground supply piping for automatic sprinkler system. A construction permit is required for the installation of the portion of the underground water supply piping, public or private, supplying a water-based fire protection system. The permit shall apply to all underground piping and appurtenances downstream of the first control valve on the lateral piping or service line from the distribution main to one foot above finished floor of the facility with the fire protection system. Maintenance performed in accordance with this code is not considered to be a modification and does not require a permit.

- EXCEPTIONS:
1. When the underground piping is installed by the aboveground piping contractor.
 2. Underground piping serves a fire protection system installed in accordance with NFPA 13D.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0105, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0105, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0105, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0105, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0105, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0202 General definitions.

SECTION 202 GENERAL DEFINITIONS

ADULT FAMILY HOME. A dwelling, licensed by Washington state, in which a person or persons provide personal care, special care, room and board to more than one but not more than six adults who are not related by blood or marriage to the person or persons providing the services.

ALERT SIGNAL. A distinctive signal indicating the need for trained personnel and occupants to initiate a specific action, such as shelter-in-place.

ALERT SYSTEM. Approved devices, equipment and systems or combinations of systems used to transmit or broadcast an alert signal.

ASSISTED LIVING FACILITY. A home or other institution, licensed by the state of Washington, providing housing, basic services and assuming general responsibility for the safety and well-being of residents under chapters 18.20 RCW and 388-78A WAC. These facilities may provide care to residents with symptoms consistent with dementia requiring additional security measures.

CHILD CARE. For the purposes of these regulations, child care is the care of children during any period of a 24-hour day.

CHILD CARE, FAMILY HOME. A child care facility, licensed by Washington state, located in the dwelling of the person or persons under whose direct care and supervision the child is placed, for the care of twelve or fewer children, including children who reside at the home.

CLUSTER. Clusters are multiple *portable school classrooms* separated by less than the requirements of the building code for separate buildings.

COVERED BOAT MOORAGE. A pier or system of floating or fixed access ways to which vessels on water may be secured and any portion of which are covered by a roof.

ELECTRICAL CODE. The National Electrical Code, promulgated by the National Fire Protection Association, as adopted by rule or local ordinance under the authority of chapter 19.28 RCW.

GRAVITY-OPERATED DROP OUT VENTS. Automatic smoke and heat vents containing heat-sensitive glazing designed to shrink and drop out of the vent openings when exposed to fire.

HOSPICE CARE CENTER. A building or portion thereof used on a 24-hour basis for the provision of hospice services to terminally ill inpatients.

MOBILE FOOD PREPERATION [PREPARATION] VEHICLE. Mobile food preparation vehicles that are equipped with appliances that produce smoke or grease-laden vapors or utilize LP-gas systems or CNG systems for the purpose of preparing and serving food to the public. Vehicles intended for private recreation shall not be considered mobile food preparation vehicles.

MOTOR VEHICLE. Includes, but not limited to, a vehicle, machine, tractor, trailer or semitrailer, or any combination thereof, propelled or drawn by mechanical power and designed for use upon the highways in the transportation of passengers or property. It does not include a vehicle, locomotive or car operated exclusively on a rail or rails, or a trolley bus operated by electric power derived from a fixed overhead wire, furnishing local passenger transportation similar to street-railway service. The term "motor vehicle" also includes freight containers or cargo tanks used, or intended for use, in connection with motor vehicles.

NIGHTCLUB. An A-2 Occupancy use under the 2006 International Building Code in which the aggregate area of concentrated use of unfixed chairs and standing space that is specifically designated and primarily used for dancing or viewing performers exceeds three hundred fifty square feet, excluding adjacent lobby areas. "Nightclub" does not include theaters with fixed seating, banquet halls, or lodge halls.

OCCUPANCY CLASSIFICATION. For the purposes of this code, certain occupancies are defined as follows:

Institutional Group I-1. Institutional Group I-1 occupancy shall include buildings, structures or portions thereof for more than 16 persons excluding staff, who reside on a 24-hour basis in a supervised environment and receive custodial care. Buildings of Group I-1 shall be classified as one of the occupancy conditions indicated below. This group shall include, but not be limited to, the following: Assisted living facilities licensed under chapter 388-78A WAC and residential treatment facilities licensed under chapter 246-337 WAC shall be classified as Group I-1, Condition 2.

Group I-2. This occupancy shall include buildings and structures used for medical care on a 24-hour basis for more than five persons who are incapable of self-preservation. This group shall include, but not be limited to, the following:

- Foster care facilities
- Detoxification facilities
- Hospice care centers
- Hospitals
- Nursing homes
- Psychiatric hospitals

Five or fewer persons receiving care. A facility such as the above with five or fewer persons receiving such care shall be classified as Group R-3 or shall comply with the *International Residential Code* provided an *automatic sprinkler system* is installed in accordance with Section 903.3.1.3 or with Section P2904 of the *International Residential Code*.

Family home child care. Family home child care licensed by Washington state for the care of twelve or fewer children shall be classified as Group R-3 or shall comply with the *International Residential Code*.

Adult care facility. A facility that provides accommodations for less than 24 hours for more than five unrelated adults and provides supervision and personal care services shall be classified as Group I-4.

EXCEPTION: Where the occupants are capable of responding to an emergency situation without physical assistance from the staff, the facility shall be classified as Group R-3.

Child care facility. Child care facilities that provide supervision and personal care on a less than 24-hour basis for more than five children 2 1/2 years of age or less shall be classified as Group I-4.

EXCEPTIONS: 1. A child day care facility that provides care for more than five but no more than 100 children 2 1/2 years or less of age, where the rooms in which the children are cared for are located on a level of exit discharge serving such rooms and each of these child care rooms has an exit door directly to the exterior, shall be classified as Group E.
2. Family child care homes licensed by Washington state for the care of 12 or fewer children shall be classified as Group R-3.

Residential Group R. Residential Group R includes, among others, the use of a building or structure, or a portion thereof, for sleeping purposes when not classified as an Institutional Group I or when not regulated by the *International Residential Code*. This group shall include:

R-1 Residential occupancies containing sleeping units where the occupants are primarily transient in nature, including:

Boarding houses (transient) with more than 10 occupants

Congregate living facilities (transient) with more than 10 occupants

Hotels (transient)

Motels (transient)

R-2 Residential occupancies containing sleeping units or more than two dwelling units where the occupants are primarily permanent in nature, including:

Apartment houses

Boarding houses (nontransient) with more than 16 occupants

Congregate living facilities (nontransient) with more than 16 occupants

Convents

Dormitories

Fraternities and sororities

Hotels (nontransient)

Live/work units

Monasteries

Motels (nontransient)

Vacation timeshare properties

R-3 Residential occupancies where the occupants are primarily permanent in nature and not classified as Group R-1, R-2, or I, including:

Buildings that do not contain more than two dwelling units.

Boarding houses (nontransient) with 16 or fewer occupants.

Boarding houses (transient) with 10 or fewer occupants.

Care facilities that provide accommodations for five or fewer persons receiving care.

Congregate living facilities (nontransient) with 16 or fewer occupants.

Congregate living facilities (transient) with 10 or fewer occupants.

Care facilities within a dwelling. Care facilities for five or fewer persons receiving care that are within a single-family dwelling are permitted to comply with the *International Residential Code* provided an automatic sprinkler system is installed in accordance with Sec-

tion 903.3.1.3 or with Section P2904 of the *International Residential Code*.

Adult family homes, family home child care. Adult family homes and family home child care facilities that are within a single-family home are permitted to comply with the *International Residential Code*.

Foster family care homes. Foster family care homes licensed by Washington state are permitted to comply with the *International Residential Code*, as an accessory use to a dwelling, for six or fewer children including those of the resident family.

R-4 Classification is not adopted. Any reference in this code to R-4 does not apply.

PORTABLE SCHOOL CLASSROOM. A prefabricated structure consisting of one or more rooms with direct exterior egress from the classroom(s). The structure is transportable in one or more sections, and is designed to be used as an educational space with or without a permanent foundation. The structure shall be capable of being demounted and relocated to other locations as needs arise.

RECALL SIGNAL. An electrically or mechanically operated signal used to recall occupants after an emergency drill or to terminate a shelter-in-place event that shall be distinct from any alarm or alert signal used to initiate an emergency plan, or other signals.

SHELTER-IN-PLACE. An emergency response used to minimize exposure of facility occupants to chemical or environmental hazards by taking refuge in predetermined interior rooms or areas where actions are taken to isolate the interior environment from the exterior hazard.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0202, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0202, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0202, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27.074, 19.27.020, and 19.27.031. WSR 14-24-090, § 51-54A-0202, filed 12/1/14, effective 5/1/15. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0202, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0307 Open burning, recreational fires and portable outdoor fireplaces.

307.2.1 Authorization. Where required by state or local law or regulations, open burning shall only be permitted with prior approval from the state or local air and water quality management authority, provided that all conditions specified in the authorization are followed. See also chapter 173-425 WAC.

307.4.2 Recreational fires. Recreational fires shall not be conducted within 25 feet of a structure or combustible material. Conditions which could cause a fire to spread within 25 feet of a structure shall be eliminated prior to ignition. See also chapter 173-425 WAC.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0307, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0308 Open flames.

308.1.4 Open-flame cooking devices. This section is not adopted.

308.1.7 Religious ceremonies. Participants in religious ceremonies shall not be precluded from carrying hand-held candles. See RCW 19.27.031(3).

308.1.7.1 Aisles and exits. Candles shall be prohibited in areas where occupants stand, or in an aisle or exit.

EXCEPTION: Candles used in religious ceremonies.

308.1.9 Decorative open flame tables. Gas-fired portable or fixed open flame fire tables and fireplaces are required to be provided with fire code official approved design or protection devices to prevent occupants from using flame, and from flame being exposed to combustible material. A fire extinguisher shall be located within 75 feet of travel distance or a distance as approved by the fire code official. Where located indoors, the supply gas valve will be interlocked with building fire alarm and/or fire sprinklers, where provided.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0308, filed 1/20/21, effective 2/20/21; WSR 16-03-055, § 51-54A-0308, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0308, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0314 Indoor displays.

314.1 General. Indoor displays constructed within any occupancy shall comply with Sections 314.2 through 314.4.

314.2 Fixtures and displays. Fixtures and displays of goods for sale to the public shall be arranged so as to maintain free, immediate and unobstructed access to exits as required by Chapter 10.

314.3 Highly combustible goods. The display of highly combustible goods including, but not limited to, fireworks, flammable or combustible liquids, liquefied flammable gases, oxidizing materials, pyroxylin plastics and agricultural goods, in main exit access aisles, corridors, covered and open malls, or within 5 feet (1524 mm) of entrances to exits and exterior exit doors is prohibited where a fire involving such goods would rapidly prevent or obstruct egress.

314.4 Vehicles. Liquid- or gas-fueled vehicles, boats, aircraft or other motorcraft shall not be located indoors except as follows:

1. The engine starting system is made inoperable, batteries are disconnected except where the fire code official requires that the batteries remain connected to maintain safety features.

2. Fuel in fuel tanks does not exceed one-quarter tank or 5 gallons (19 L) (whichever is least).

3. Fuel tanks and fill openings are closed and sealed to prevent tampering.

4. Vehicles, aircraft, boats or other motorcraft equipment are not fueled or defueled within the building.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0314, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0314, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-0315 General storage.

**Table 315.7.6(1)
Separation Distance Between Pallet
Stack and Building**

| Wall Construction | Opening Type | Wood Pallet Separation Distance (feet) | | |
|---------------------------|---|--|-------------------|---------------|
| | | ≤ 50 Pallets | 51 to 200 Pallets | > 200 Pallets |
| Masonry | None | 2 | 2 | 2 |
| Masonry | Fire-rated glazing with open sprinklers | 2 | 5 | 20 |
| Masonry | Fire-rated glazing | 5 | 10 | 20 |
| Masonry | Plain glass with open sprinklers | 5 | 10 | 20 |
| Noncombustible | None | 5 | 10 | 20 |
| Wood with open sprinklers | _____ | 5 | 10 | 20 |
| Wood | None | 15 | 30 | 90 |
| Any | Plain glass | 15 | 30 | 90 |

For SI: 1 foot = 304.8 mm

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-0315, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-0319 Mobile food preparation vehicles.

319.1 General. Mobile food preparation vehicles that are equipped with appliances that produce smoke or grease-laden vapors or utilize LP-gas systems or CNG systems shall comply with this section.

[Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0319, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-0319, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-0401 General.

401.2 Approval. Where required by the fire code official, fire safety plans, emergency procedures and employee training programs shall be approved by the fire official.

[Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0401, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0401, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0402 Definitions. The following terms are defined in Chapter 2:

ALARM SIGNAL

ALERT SIGNAL

ALERT SYSTEM

SHELTER-IN-PLACE

RECALL SIGNAL

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0402, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0402, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0403 Emergency preparedness requirements.

403.3.1 Fire evacuation plan. The fire safety and evacuation plan required by Section 404 shall include a description of special staff actions. This shall include a description for stabilizing patients in a staged evacuation or full evacuation in conjunction with the entire building, if part of a multitenant facility.

403.5.4 Assembly points and fire operations. Assembly points shall not be in areas likely to be utilized for fire service operations.

403.10.2 Group R-2 occupancies. Group R-2 occupancies shall comply with Sections 403.10.2.1 through 403.10.2.4.

403.10.2.4 Group R-2 assisted living and residential care facilities. Assisted living and residential care facilities licensed by the state of Washington shall comply with Section 403.8.1 as required for Group I-1 Condition 2 occupancies.

403.10.3 Group R-4 occupancies. This section not adopted.

403.12.3 Crowd managers for gatherings exceeding 1,000 people. Where facilities or events involve a gathering of more than 1,000 people, or as required by the fire code official, crowd managers shall be provided in accordance with Sections 403.12.3.1 through 403.12.3.3.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0403, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-0404 Fire safety and evacuation plans.

404.2.3 Lockdown plans. This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0404, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0404, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0405 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0405, filed 12/18/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0405, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0405, filed 1/16/16, effective 7/1/16; WSR 13-20-118, § 51-54A-0405, filed 10/1/13, effective 11/1/13. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters

19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0405, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0406 Employee training and response procedures.

406.1 General. Employees in the occupancies listed in Section 403 shall be trained in the emergency procedures described in their emergency plans. Training shall be based on these plans and as described in Section 406.2 [and 406.3][through 406.3.4].

406.2 Frequency. Employees shall receive training in the contents of the emergency plans and their duties as part of new employee orientation and at least annually thereafter. Records shall be kept and made available to the fire code official upon request.

406.3 Employee training program. Employees shall be trained in fire prevention, evacuation, sheltering-in-place, and fire safety in accordance with Sections 406.3.1 through [406.3.3][406.3.4].

406.3.4 Emergency shelter-in-place training. Where a facility has a shelter-in-place plan, employees shall be trained on the alert and recall signals, communication system, location of emergency supplies, the use of the incident notification and alarm system, and their assigned duties and procedures in the event of an alarm or emergency.

[**406.4 Emergency lockdown training.** This section is not adopted.]

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0406, filed 1/20/21, effective 2/20/21. Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0406, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0406, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0406, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0406, filed 2/1/13, effective 7/1/13.]

Reviser's note: RCW 34.05.395 requires the use of underlining and deletion marks to indicate amendments to existing rules, and deems ineffectual changes not filed by the agency in this manner. The bracketed material in the above section does not appear to conform to the statutory requirement.

WAC 51-54A-0408 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0408, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0408, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0503 Fire apparatus access roads.

503.1 Where required. Fire apparatus access roads shall be provided and maintained in accordance with locally adopted street, road, and access standards.

503.1.1 Buildings and facilities, is not adopted.

503.1.2 Additional access, is not adopted.

503.1.3 High-piled storage, is not adopted.

503.2 Specifications. This section is not adopted.

503.3 Marking. This section is not adopted.

503.4 Obstruction of fire apparatus access roads. This section is not adopted.

503.4.1 Traffic calming devices. This section is not adopted.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0503, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0507 Fire protection water supplies.

507.3 Fire flow. Fire flow requirements for buildings or portions of buildings and facilities shall be determined by an approved method.

EXCEPTIONS: 1. Fire flow is not required for structures under 500 square feet with a B, U or R-1 occupancy where structures are at least 30 feet from any other structure and are used only for recreation.
2. In rural and suburban areas in which adequate and reliable water supply systems do not exist, the fire *code official* is authorized to utilize NFPA 1142 or the *International Wildland-Urban Interface Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0507, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0507, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0508 Fire command center.

508.1.2 Separation. The fire command center shall be separated from the remainder of the building by not less than a 2-hour fire barrier constructed in accordance with Section 707 of the International Building Code or horizontal assembly constructed in accordance with Section 711 of the International Building Code, or both.

[Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0508, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0508, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0510 Emergency responder radio coverage.

510.4.1.1 Minimum signal strength into building. The minimum inbound signal strength shall be sufficient to provide usable voice communications throughout the coverage area as specified by the *fire code official*. The inbound signal level shall be a minimum of -95 dBm throughout the coverage area and sufficient to provide not less than a delivered audio quality (DAQ) of 3.0 or an equivalent signal-to-interference-plus-noise ratio (SINR) applicable to the technology for either analog or digital signals.

510.4.2.4 Signal booster requirements. If used, signal boosters shall meet the following requirements:

1. All signal booster components shall be a National Electrical Manufacturer's Association (NEMA) 4, IP65-type waterproof cabinet or equivalent.

2. Battery systems used for the emergency power source shall be contained in a NEMA 3R or higher-rated cabinet, IP65-type waterproof cabinet or equivalent.

3. Equipment shall have FCC or other radio licensing authority certification and be suitable for public safety use prior to installation.

4. Where a donor antenna exists, isolation shall be maintained between the donor antenna and all inside antennas to not less than 20 dB greater than the system gain under all operating conditions.

5. Bi-directional amplifiers (BDAs) active RF emitting devices used in emergency responder radio coverage systems shall have oscillation prevention built-in oscillation detection and control circuitry.

6. The installation of amplification systems or systems that operate on or provide the means to cause interference on any emergency responder radio coverage networks shall be coordinated and approved by the fire code official.

510.5.3 Acceptance test procedure. Where an emergency responder radio coverage system is required, and upon completion of installation, the building owner shall have the radio system tested to verify that two-way coverage on each floor of the building is not less than 95 percent. The test procedure shall be conducted as follows:

1. Each floor of the building shall be divided into a grid of 20 approximately equal test areas.

2. The test shall be conducted using a calibrated portable radio of the latest brand and model used by the agency talking through the agency's radio communications system or equipment approved by the fire code official.

3. Failure of more than one test area shall result in failure of the test.

4. In the event that two of the test areas fail the test, in order to be more statistically accurate, the floor shall be permitted to be divided into 40 equal test areas. Failure of not more than two non-adjacent test areas shall not result in failure of the test. If the system fails the 40 area test, the system shall be altered to meet the 95 percent coverage requirement.

5. A test location approximately in the center of each test area shall be selected for the test, with the radio enabled to verify two-way communications to and from the outside of the building through the public agency's radio communications system. Once the test location has been selected, that location shall represent the entire test area. Failure in the selected test location shall be considered to be a failure of that test area. Additional test locations shall not be permitted.

6. The gain values of all amplifiers shall be measured and the test measurement results shall be kept on file with the building owner so that the measurements can be verified during annual tests. In the event that the measurement results become lost, the building owner shall be required to rerun the acceptance test to reestablish the gain values.

7. As part of the installation, a spectrum analyzer or other suitable test equipment shall be utilized to ensure spurious oscillations are not being generated by the subject signal booster. This test shall be conducted at the time of installation and at subsequent annual inspections.

8. Systems incorporating Class B signal-booster devices or Class B broadband fiber remote devices shall be tested using two portable

radios simultaneously conducting subjective voice quality checks. One portable radio shall be positioned not greater than 10 feet (3048 mm) from the indoor antenna. The second portable radio shall be positioned at a distance that represents the farthest distance from any indoor antenna. With both portable radios simultaneously keyed up on different frequencies within the same band, subjective audio testing shall be conducted and comply with DAQ levels as specified in Sections 510.4.1.1 and 510.4.1.2.

510.5 Installation requirements. The installation of the public safety radio coverage system shall be in accordance with NFPA 1221 and Sections 510.5.1 through 510.5.5.

510.5.5 Mounting of the donor antenna(s). To maintain proper alignment with the system designed donor site, donor antennas shall be permanently affixed on the highest possible position on the building or where approved by the fire code official. A clearly visible sign stating "movement or repositioning of this antenna is prohibited without approval from the fire code official." The antenna installation shall be in accordance with the applicable requirements in the International Building Code for weather protection of the building envelope.

510.6.1 Testing and proof of compliance. The owner of the building or owner's authorized agent shall have the emergency responder radio coverage system inspected and tested annually or where structural changes occur including additions or remodels that could materially change the original field performance tests. Testing shall consist of the following:

1. In-building coverage test as described in Section 510.5.3 or as required by the fire code official.
2. Signal boosters shall be tested to verify that the gain is the same as it was upon initial installation and acceptance or set to optimize the performance of the system.
3. Backup batteries and power supplies shall be tested under load of a period of 1 hour to verify that they will properly operate during an actual power outage. If within the 1-hour test period the battery exhibits symptoms of failure, the test shall be extended for additional 1-hour periods until the integrity of the battery can be determined.
4. Other active components shall be checked to verify operation within the manufacturers specification.
5. At the conclusion of the testing, a report, which shall verify compliance with Section 510.5.3, shall be submitted to the fire code official.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0510, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0510, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-0605 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0605, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 17-18-060, § 51-54A-0605, filed 9/1/17, effective 10/2/17. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0605, filed 4/25/17, effective 5/26/17. Statutory Authority:

RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0605, filed 1/16/16, effective 7/1/16. Statutory Authority: Chapters 19.27A and 34.05 RCW. WSR 13-24-076, § 51-54A-0605, filed 12/2/13, effective 4/1/14. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0605, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0607 Section 607—Commercial kitchen hoods.

[M] 607.2 Where required. A Type I hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease laden vapors.

EXCEPTIONS:

1. Factory-built commercial exhaust hoods that are listed and labeled in accordance with UL 710, and installed in accordance with Section 304.1 of the *International Mechanical Code*, shall not be required to comply with Sections 507.1.5, 507.2.3, 507.2.5, 507.2.8, 507.3.1, 507.3.3, 507.4 and 507.5 of the *International Mechanical Code*.
2. Factory-built commercial cooking recirculating systems that are listed and labeled in accordance with UL 710B, and installed in accordance with Section 304.1 of the *International Mechanical Code*, shall not be required to comply with Sections 507.1.5, 507.2.3, 507.2.5, 507.2.8, 507.3.1, 507.3.3, 507.4 and 507.5 of the *International Mechanical Code*. Spaces in which such systems are located shall be considered to be kitchens and shall be ventilated in accordance with Table 403.3.1.1 of the *International Mechanical Code*. For the purpose of determining the floor area required to be ventilated, each individual appliance shall be considered as occupying not less than 100 square feet (9.3 m²).
3. Where cooking appliances are equipped with integral down-draft exhaust systems and such appliances and exhaust systems are listed and labeled for the application in accordance with NFPA 96, a hood shall not be required at or above them.
4. A Type I hood shall not be required for an electric cooking appliance where an approved testing agency provides documentation that the appliance effluent contains 5 mg/m³ or less of grease when tested at an exhaust flow rate of 500 cfm (0.236 m³/s) in accordance with UL 710B.
5. A Type I hood shall not be required to be installed in an R-2 occupancy with not more than 16 residents.

607.2.1 Domestic cooking appliances used for commercial purposes. Domestic cooking appliances utilized for commercial purposes shall be provided with Type I, Type II, or residential hoods as required for the type of appliances and processes in accordance with Table 607.2.1 and Sections 507.2 and 507.3 of the *International Mechanical Code*.

**Table 607.2.1
Type of Hood Required for Domestic
Cooking Appliances in the Following
Spaces^{a, b}**

| Type of Space | Type of Cooking | Type of Hood |
|--|--|--|
| Church | 1. Boiling, steaming, and warming precooked food | Residential hood ^c or Type II hood |
| | 2. Roasting, pan frying, and deep frying | Type I hood |
| Community or party room in apartment and condominium | 1. Boiling, steaming, and warming precooked food | Residential hood ^c or Type II hood ^d |
| | 2. Roasting, pan frying, and deep frying | Type I hood |
| Day care | 1. Boiling, steaming, and warming precooked food | Residential hood ^c or Type II hood ^d |
| | 2. Roasting, pan frying, and deep frying | Type I hood |

| Type of Space | Type of Cooking | Type of Hood |
|---|--|--|
| Dormitory, assisted living facility, nursing home | 1. Boiling, steaming, and warming precooked food | Residential hood ^c or Type II hood |
| | 2. Roasting, pan frying, and deep frying | Type I hood |
| Office lunch room | 1. Boiling, steaming, and warming precooked food | Residential hood ^c or Type II hood ^d |
| | 2. Roasting, pan frying, and deep frying | Type I hood |

a Commercial cooking appliances shall comply with Section 507.2 of the *International Mechanical Code*.

b Requirements in this table apply to electric or gas fuel appliances only. Solid fuel appliances or charbroilers require Type I hoods.

c Residential hood shall ventilate to the outside.

d Type II hood required when more than one appliance is used.

607.3 Operations, inspection, and maintenance. Commercial cooking systems shall be operated, inspected, and maintained in accordance with Sections 607.3.1 through 607.3.4 and Chapter 11 of NFPA 96.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0607, filed 1/20/21, effective 2/20/21; WSR 20-01-162, § 51-54A-0607, filed 12/18/19, effective 7/1/20.]

Reviser's note: The brackets and enclosed material in the text of the above section occurred in the copy filed by the agency.

WAC 51-54A-0609 Reserved.

[Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-02-059, § 51-54A-0609, filed 1/4/21, effective 2/4/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-0609, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0609, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0609, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0701 General.

701.6 Owner's responsibility. The owner shall maintain an inventory of all required fire-resistance-rated construction, construction installed to resist the passage of smoke and the construction included in Sections 703 through 707 and Sections 602.4.1 and 602.4.2 of the *International Building Code*. Such construction shall be visually inspected by the owner annually and properly repaired, restored or replaced where damaged, altered, breached or penetrated. Records of inspections and repairs shall be maintained. Where concealed, such elements shall not be required to be visually inspected by the owner unless the concealed space is accessible by the removal or movement of a panel, access door, ceiling tile or similar movable entry to the space.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0701, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-0701, filed 1/2/19, effective 7/1/19.]

WAC 51-54A-0806 Decorative vegetation in new and existing buildings.

806.1.1 Restricted occupancies. Natural cut trees shall be prohibited in the following occupancies:

1. Group I; and
2. R-2 occupancies providing licensed care to clients in one of the categories listed in the International Building Code, Section 310.1, licensed by Washington state.

806.1.2 Support devices. The support device that holds the tree in an upright position shall be of a type that is stable and that meets all of the following criteria:

1. The device shall hold the tree securely and be of adequate size to avoid tipping over of the tree.
2. The device shall be capable of containing a minimum supply of water in accordance with Table 806.1.2.
3. The water level, when full, shall cover the tree stem at least 2 inches (51 mm). The water level shall be maintained above the fresh cut and checked at least once daily.

**Table 806.1.2
Support Stand Water Capacity**

| Tree Stem Diameter (inches) | Minimum Support Stand Water Capacity (gallons) | Typical Daily Water Transpiration Amount (gallons) |
|-----------------------------|--|--|
| Up to 4 | 1 | 1/4 to 1 |
| 4 to 6 | 1 1/2 | 1 1/4 to 1 1/2 |
| 7 to 8 | 2 | 1 3/4 to 2 |
| 9 to 12 | 3 | 2 1/4 to 3 |
| 13 and over | 4 | Over 3 |

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0806, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0901 General.

901.4.2 Nonrequired fire protection systems. A fire protection system or portion thereof not required by this code or the *International Building Code* shall be allowed to be furnished for partial or complete protection provided such installed system meets the applicable requirements of this code and the *International Building Code*. Such systems or portion of system shall be provided with signage stating "NON-REQUIRED SYSTEM." Signage shall be durable and permanent in nature, with contrasting color and background, and with lettering of not less than 1 inch in height. Location of such signage shall be approved.

901.8.2 Removal of existing occupant-use hose lines. The fire code official is authorized to permit the removal of existing occupant-use hose lines where all of the following conditions exist:

1. Installation is not required by this code, the *International Building Code*, or a previously approved alternative method.
2. The hose line would not be utilized by trained personnel or the fire department.
3. The remaining outlets are compatible with local fire department fittings.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0901, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-0903 Automatic sprinkler systems.

903.2.1.6 Assembly occupancies on roofs. Where an occupied roof has an assembly occupancy with an occupant load exceeding 100 for Group A-2, and 300 for other Group A occupancies, the building shall be equipped with an *automatic sprinkler system* in accordance with Section 903.3.1.1 or 903.3.1.2.

EXCEPTION: Open parking garages of Type I or Type II construction.

903.2.1.8 Nightclub. An automatic sprinkler system shall be provided throughout Group A-2 nightclubs as defined in this code.

903.2.3 Group E. An automatic sprinkler system shall be provided for fire areas containing Group E occupancies where the fire area has an occupant load of 51 or more, calculated in accordance with Table 1004.1.2.

EXCEPTIONS:

1. Portable school classrooms with an occupant load of 50 or less calculated in accordance with Table 1004.1.2, provided that the aggregate area of any cluster of portable classrooms does not exceed 6,000 square feet (557 m²); and clusters of portable school classrooms shall be separated as required by the building code; or
2. Portable school classrooms with an occupant load from 51 through 98, calculated in accordance with Table 1004.1.2, and provided with two means of direct independent exterior egress from each classroom in accordance with Chapter 10, and one exit from each classroom shall be accessible, provided that the aggregate area of any cluster of portable classrooms does not exceed 6,000 square feet (557 m²); and clusters of portable school classrooms shall be separated as required by the building code; or
3. Fire areas containing day care and preschool facilities with a total occupant load of 100 or less located at the level of exit discharge where every room in which care is provided has not fewer than one exit discharge door.

903.2.6 Group I. An automatic sprinkler system shall be provided throughout buildings with a Group I *fire area*.

EXCEPTIONS:

1. An *automatic sprinkler system* installed in accordance with Section 903.3.1.2 shall be permitted in Group I-1 Condition 1 facilities.
2. Where new construction or additions house less than sixteen persons receiving care, an automatic sprinkler system installed in accordance with Section 903.2.8.3 shall be permitted for Group I-1, Condition 2, assisted living facilities licensed under chapter 388-78A WAC and residential treatment facilities licensed under chapter 246-337 WAC.

903.2.6.1 Group I-4. An automatic sprinkler system shall be provided in fire areas containing Group I-4 occupancies where the fire area has an occupant load of 51 or more, calculated in accordance with Table 1004.1.2.

EXCEPTIONS:

1. An automatic sprinkler system is not required where Group I-4 day care facilities with a total occupant load of 100 or less, and located at the level of exit discharge and where every room where care is provided has not fewer than one exterior exit door.
2. In buildings where Group I-4 day care is provided on levels other than the level of exit discharge, an automatic sprinkler system in accordance with Section 903.3.1.1 shall be installed on the entire floor where care is provided, all floors between the level of care and the level of exit discharge and all floors below the level of exit discharge other than areas classified as an open parking garage.

903.2.8 Group R. An automatic sprinkler system installed in accordance with Section 903.3 shall be provided throughout all buildings with a Group R *fire area*.

EXCEPTION:

Group R-1 if all of the following conditions apply:

1. The Group R fire area is no more than 500 square feet and is used for recreational use only.
2. The Group R fire area is on only one story.
3. The Group R fire area does not include a basement.
4. The Group R fire area is no closer than 30 feet from another structure.
5. Cooking is not allowed within the Group R fire area.

6. The Group R fire area has an occupant load of no more than 8.
7. A hand-held (portable) fire extinguisher is in every Group R fire area.

903.2.9 Group S-1. An automatic sprinkler system shall be provided throughout all buildings containing a Group S-1 occupancy where one of the following conditions exists:

1. A Group S-1 fire area exceeds 12,000 square feet (1115 m²).
2. A Group S-1 fire area is located more than three stories above grade plane.
3. The combined area of all Group S-1 fire areas on all floors, including any mezzanines, exceeds 24,000 square feet (2230 m²).
4. A Group S-1 fire area used for the storage of commercial motor vehicles where the fire area exceeds 5,000 square feet (464 m²).

903.2.9.3 Group S-1 Upholstered furniture and mattresses. An automatic sprinkler system shall be provided throughout a Group S-1 fire where the area used for the storage of upholstered furniture exceeds 2,500 square feet (232 m²).

EXCEPTION: Self-service storage facilities no greater than one story above grade plane where all storage spaces can be accessed directly from the exterior.

903.2.11.1.3 Basements. Where any portion of a basement is located more than 75 feet (22,860 mm) from openings required by Section 903.2.11.1, or where new walls, partitions or other similar obstructions are installed that increase the exit access travel distance to more than 75 feet, the basement shall be equipped throughout with an approved automatic sprinkler system.

903.2.11.7 Relocatable buildings within buildings. Relocatable buildings or structures located within a building with an approved fire sprinkler system shall be provided with fire sprinkler protection within the occupiable space of the building and the space underneath the relocatable building.

EXCEPTIONS:

1. Sprinkler protection is not required underneath the building when the space is separated from the adjacent space by construction resisting the passage of smoke and heat and combustible storage will not be located there.
2. If the building or structure does not have a roof or ceiling obstructing the overhead sprinklers.
3. Construction trailers and temporary offices used during new building construction prior to occupancy.
4. Movable shopping mall kiosks with a roof or canopy dimension of less than 4 feet on the smallest side.

903.3.5.3 Underground portions of fire protection system water supply piping. The portion of the installation or modification of an underground water main, public or private, dedicated to supplying a water-based fire protection system shall be in accordance with NFPA 24 and chapter 18.160 RCW. Piping and appurtenances downstream of the first control valve on the lateral or service line from the distribution main to one-foot above finished floor shall be approved by the fire code official. Such underground piping shall be installed by a fire sprinkler system contractor licensed in accordance with chapter 18.160 RCW and holding either a Level U or a Level 3 license. For underground piping supplying systems installed in accordance with Section 903.3.1.2, a Level 2, 3, or U licensed contractor is acceptable.

EXCEPTION: Portions of underground piping supplying automatic sprinkler systems installed in accordance with NFPA 13D.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0903, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-0903, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0903, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0903, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27.074, 19.27.020, and 19.27.031.

WSR 14-24-090, § 51-54A-0903, filed 12/1/14, effective 5/1/15. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0903, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0904 Alternative automatic fire-extinguishing systems.

904.1.1 Certification of service personnel for fire-extinguishing equipment. Service personnel performing system design, installation or conducting system maintenance or testing on automatic fire-extinguishing systems, other than automatic sprinkler systems, shall possess the appropriate ICC/NAFED certification.

904.1.1.1 Preengineered kitchen fire-extinguishing systems. A current ICC/NAFED certification for preengineered kitchen fire-extinguishing systems is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1.2 Engineered fire suppression systems. A current ICC/NAFED certification for engineered fire suppression systems is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.1.1.3 Preengineered industrial fire-extinguishing system. A current ICC/NAFED certification for preengineered industrial fire-extinguishing system is required when performing design, installation, inspection/testing or maintenance on kitchen suppression systems.

904.12 Commercial cooking systems. The automatic fire-extinguishing system for commercial cooking systems shall be of a type recognized for protection of commercial cooking equipment and exhaust systems of the type and arrangement protected. Preengineered automatic dry and wet chemical extinguishing systems shall be tested in accordance with UL 300 and listed and labeled for the intended application. Other types of automatic fire-extinguishing systems shall be listed and labeled for specific use as protection for commercial cooking operations. The system shall be installed in accordance with this code, its listing and the manufacturer's installation instructions. Signage shall be provided on the exhaust hood or system cabinet, indicating the type and arrangement of cooking appliances protected by the automatic fire-extinguishing system. Signage shall indicate appliances from left to right, be durable, and the size, color, and lettering shall be approved. Automatic fire-extinguishing systems of the following types shall be installed in accordance with the referenced standard indicated, as follows:

1. Carbon dioxide extinguishing systems, NFPA 12;
2. *Automatic sprinkler systems*, NFPA 13;
3. Foam-water sprinkler systems or foam-water spray systems, NFPA 16;
4. Dry-chemical extinguishing systems, NFPA 17;
5. Wet-chemical extinguishing systems, NFPA 17A.

EXCEPTION: Factory-built commercial cooking recirculating systems that are tested in accordance with UL 710B and *listed, labeled* and installed in accordance with Section 304.1 of the *International Mechanical Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-0904, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0904, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-0907 Fire alarm and detection systems.

907.2.3 Group E. Group E occupancies shall be provided with a manual fire alarm system that initiates the occupant notification signal utilizing one of the following:

1. An emergency voice/alarm communication system meeting the requirements of Section 907.5.2.2 and installed in accordance with Section 907.6; or

2. A system developed as part of a safe school plan adopted in accordance with RCW 28A.320.125 or developed as part of an emergency response system consistent with the provisions of RCW 28A.320.126. The system must achieve all of the following performance standards:

2.1 The ability to broadcast voice messages or customized announcements;

2.2 Includes a feature for multiple sounds, including sounds to initiate a lock down;

2.3 The ability to deliver messages to the interior of a building, areas outside of a building as designated pursuant to the safe school plan, and to personnel;

2.4 The ability for two-way communications;

2.5 The ability for individual room calling;

2.6 The ability for a manual override;

2.7 Installation in accordance with NFPA 72;

2.8 Provide 15 minutes of battery backup for alarm and 24 hours of battery backup for standby; and

2.9 Includes a program for annual inspection and maintenance in accordance with NFPA 72.

EXCEPTIONS:

1. A manual fire alarm system is not required in Group E occupancies with an occupant load of 50 or less.

2. Emergency voice/alarm communication systems meeting the requirements of Section 907.5.2.2 and installed in accordance with Section 907.6 shall not be required in Group E occupancies with occupant loads of 100 or less, such as individual portable school classroom buildings; provided that activation of the manual fire alarm system initiates an approved occupant notification signal in accordance with Section 907.5.

3. Where an existing approved alarm system is in place, an emergency voice/alarm system is not required in any portion of an existing Group E building undergoing any one of the following repairs, alteration or addition:

3.1 Alteration or repair to an existing building including, without limitation, alterations to rooms and systems, and/or corridor configurations, not exceeding 35 percent of the fire area of the building (or the fire area undergoing the alteration or repair if the building is comprised of two or more fire areas); or

3.2 An addition to an existing building, not exceeding 35 percent of the fire area of the building (or the fire area to which the addition is made if the building is comprised of two or more fire areas).

4. Manual fire alarm boxes are not required in Group E occupancies where all of the following apply:

4.1 Interior corridors are protected by smoke detectors.

4.2 Auditoriums, cafeterias, gymnasiums and similar areas are protected by heat detectors or other approved detection devices.

4.3 Shops and laboratories involving dusts or vapors are protected by heat detectors or other approved detection devices.

5. Manual fire alarm boxes shall not be required in Group E occupancies where all of the following apply:

5.1 The building is equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1.

5.2 The emergency voice/alarm communication system will activate on sprinkler waterflow.

5.3 Manual activation is provided from a normally occupied location.

907.2.3.1 Sprinkler systems or detection. When automatic sprinkler systems or smoke detectors are installed, such systems or detectors shall be connected to the building fire alarm system.

907.2.6.1 Group I-1. An automatic smoke detection system shall be installed in *corridors*, waiting areas open to *corridors* and *habitable spaces* other than *sleeping units* and kitchens. The system shall be activated in accordance with Section 907.4.

EXCEPTIONS:

1. For Group I-1 Condition 1 occupancies, smoke detection in *habitable spaces* is not required where the facility is equipped throughout with an *automatic sprinkler system* installed in accordance with Section 903.3.1.1.

2. Smoke detection is not required for exterior balconies.

907.2.6.4 Group I-4 occupancies. A manual fire alarm system that initiates the occupant notification signal utilizing an emergency voice/alarm communication system meeting the requirements of Section 907.5.2.2 and installed in accordance with Section 907.6 shall be installed in Group I-4 occupancies. When automatic sprinkler systems or

smoke detectors are installed, such systems or detectors shall be connected to the building fire alarm system.

EXCEPTIONS:

1. A manual fire alarm system is not required in Group I-4 occupancies with an occupant load of 50 or less.
2. Emergency voice alarm communication systems meeting the requirements of Section 907.5.2.2 and installed in accordance with Section 907.6 shall not be required in Group I-4 occupancies with occupant loads of 100 or less, provided that activation of the manual fire alarm system initiates an approved occupant notification signal in accordance with Section 907.5.

907.5.2.1.2 Maximum sound pressure. The maximum sound pressure level for audible alarm notification appliances shall be 110 dBA at the minimum hearing distance from the audible appliance. For systems operating in public mode, the maximum sound pressure level shall not exceed 30 dBA over the average ambient sound level. Where the average ambient noise is greater than 95 dBA, visible alarm notification appliances shall be provided in accordance with NFPA 72 and audible alarm notification appliances shall not be required.

907.10.1 Testing/maintenance: All inspection, testing, maintenance and programming not defined as "*electrical construction trade*" by chapter 19.28 RCW shall be completed by a NICET II or ESA/NTS Certified Fire Alarm Technician (CFAT) Level II Fire in fire alarms (effective July 1, 2018).

907.11 NICET: National Institute for Certification in Engineering Technologies and ESA/NTS: Electronic Security Association/National Training School.

907.11.1 Scope. This section shall apply to new and existing fire alarm systems.

907.11.2 Design review: All construction documents shall be reviewed by a NICET III, an ESA/NTS Certified Fire Alarm Designer (CFAD) Level III Fire in fire alarms, or a licensed professional engineer (PE) in Washington prior to being submitted for permitting. The reviewing professional shall submit a stamped, signed, and dated letter; or a verification method approved by the local authority having jurisdiction indicating the system has been reviewed and meets or exceeds the design requirements of the state of Washington and the local jurisdiction (effective July 1, 2018).

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0907, filed 1/20/21, effective 2/20/21; WSR 20-01-162, § 51-54A-0907, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-0907, filed 1/2/19, effective 7/1/19. Statutory Authority: RCW 19.27.074 and 19.27.550. WSR 18-01-104, § 51-54A-0907, filed 12/19/17, effective 7/1/18. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0907, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0907, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27.074, 19.27.020, and 19.27.031. WSR 14-24-091, § 51-54A-0907, filed 12/1/14, effective 5/1/15. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0907, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0908 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0908, filed 1/16/16, effective 7/1/16. Statutory Authority: Chapters 19.27, 19.27A, and 34.05 RCW. WSR 13-24-017, § 51-54A-0908,

filed 11/21/13, effective 4/1/14. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0908, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0909 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0909, filed 1/20/21, effective 2/20/21; WSR 20-01-162, § 51-54A-0909, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0909, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0909, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0915 Carbon monoxide detection.

915.1 General. Carbon monoxide detection shall be installed in new buildings in accordance with Sections 915.1.1 through 915.6. Carbon monoxide detection shall be installed in existing buildings in accordance with Chapter 11 of the *International Fire Code*.

915.1.1 Where required. Carbon monoxide detection shall be provided in Group I and R occupancies and in classrooms in Group E occupancies in the locations specified in Section 915.2 where any of the conditions in Sections 915.1.2 through 915.1.6 exist.

EXCEPTIONS: 1. R-2 occupancies, with the exception of R-2 college dormitories, are required to install carbon monoxide detectors without exception.
2. Sleeping units or dwelling units in I and R-1 occupancies and R-2 college dormitories, hotel, DOC prisons and work releases and assisted living facilities and residential treatment facilities licensed by the state of Washington, which do not themselves contain a fuel-burning appliance, a fuel-burning fireplace, or have an attached garage, need not be provided with carbon monoxide alarms provided that they comply with the exceptions of Section 915.1.4.

915.2.1 Dwelling units. Carbon monoxide detection shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms and on each level of the dwelling. Where a fuel-burning appliance or a fuel-burning fireplace is located within a bedroom or its attached bathroom, carbon monoxide detection shall be installed within the bedroom.

915.2.2 Sleeping units. Carbon monoxide detection shall be installed in *sleeping units*.

EXCEPTION: Carbon monoxide detection shall be allowed to be installed outside of each separate sleeping area in the immediate vicinity of the sleeping unit where the sleeping unit or its attached bathroom does not contain a fuel-burning appliance or fuel-burning fireplace and is not served by a forced air furnace.

915.2.3 Group E occupancies. When required by Section 915.1 in new buildings, or by Chapter 11 of the *International Fire Code*, carbon monoxide detection shall be installed in classrooms in Group E occupancies. Carbon monoxide alarm signals shall be automatically transmitted to an on-site location that is staffed by school personnel.

EXCEPTIONS: 1. Carbon monoxide alarm signals shall not be required to be automatically transmitted to an on-site location that is staffed by school personnel in Group E occupancies with an occupant load of 50 or less.
2. Carbon monoxide alarm signals shall not be required to be automatically transmitted to an on-site location that is staffed by school personnel in Group E occupancies where an exception contained in Section 915.1 applies, or in Group E occupancies where signals are transmitted to an off-site service monitored by a third party, such as a service that monitors fire protection systems in the building.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0915, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0915, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0915, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-0916 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0916, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0916, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-0918 Alerting systems.

918.1 General. An approved alerting system shall be provided in buildings and structures as required in Chapter 4 and this section, unless other requirements are provided by another section of this code.

EXCEPTION: Approved alerting systems in existing buildings, structures or occupancies.

918.2 Power source. Alerting systems shall be provided with power supplies in accordance with Section 4.4.1 of NFPA 72 and circuit disconnecting means identified as "EMERGENCY ALERTING SYSTEM."

EXCEPTION: Systems which do not require electrical power to operate.

918.3 Duration of operation. The alerting system shall be capable of operating under nonalarm condition (quiescent load) for a minimum of 24 hours and then shall be capable of operating during an emergency condition for a period of 15 minutes at maximum connected load.

918.4 Combination system. Alerting system components and equipment shall be allowed to be used for other purposes.

918.4.1 System priority. The alerting system use shall take precedence over any other use.

918.4.2 Fire alarm system. Fire alarm systems sharing components and equipment with alerting systems must be in accordance with Section 6.8.4 of NFPA 72.

918.4.2.1 Signal priority. Recorded or live alert signals generated by an alerting system that shares components with a fire alarm system shall, when actuated, take priority over fire alarm messages and signals.

918.4.2.2 Temporary deactivation. Should the fire alarm system be in the alarm mode when such an alerting system is actuated, it shall temporarily cause deactivation of all fire alarm-initiated audible messages or signals during the time period required to transmit the alert signal.

918.4.2.3 Supervisory signal. Deactivation of fire alarm audible and visual notification signals shall cause a supervisory signal for each notification zone affected in the fire alarm system.

918.5 Audibility. Audible characteristics of the alert signal shall be in accordance with Section 7.4.1 of NFPA 72 throughout the area served by the alerting system.

EXCEPTION: Areas served by approved visual or textual notification, where the visible notification appliances are not also used as a fire alarm signal, are not required to be provided with audibility complying with Section 916.6.

918.6 Visibility. Visible and textual notification appliances shall be permitted in addition to alert signal audibility.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0918, filed 12/18/19, effective 7/1/20.]

WAC 51-54A-1007 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1007, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1007, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1008 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1008, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1008, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1009 Accessible means of egress.

1009.1 Accessible means of egress required. Accessible means of egress shall comply with this section. Accessible spaces shall be provided with not less than one accessible means of egress. Where more than one means of egress is required by Section 1006.2 or 1006.3 from any accessible space, each accessible portion of the space shall be served by not less than two accessible means of egress.

EXCEPTIONS:

1. One accessible means of egress is required from an accessible mezzanine level in accordance with Section 1009.3, 1009.4 or 1009.5.
2. In assembly areas with ramped aisles or stepped aisles one accessible means of egress is permitted where the common path of egress travel is accessible and meets the requirements in Section 1029.8.
3. In parking garages, accessible means of egress are not required to serve parking areas that do not contain accessible parking spaces.

1009.8 Two-way communication. A two-way communication system complying with Sections 1009.8.1 and 1009.8.2 shall be provided at the landing serving each elevator or bank of elevators on each accessible floor that is one or more stories above or below the level of exit discharge.

EXCEPTIONS:

1. Two-way communication systems are not required at the landing serving each elevator or bank of elevators where the two-way communication system is provided within areas of refuge in accordance with Section 1009.6.5.
2. Two-way communication systems are not required on floors provided with ramps that provide a direct path of egress travel to grade or the level of exit discharge conforming to the provisions of Section 1012.
3. Two-way communication systems are not required at the landings serving only service elevators that are not designated as part of the accessible means of egress or serve as part of the required accessible route into a facility.
4. Two-way communication systems are not required at the landings serving only freight elevators.
5. Two-way communication systems are not required at the landing serving a private residence elevator.
6. Two-way communication systems are not required in Group I-2 or I-3 facilities.

1009.8.1 System requirements. Two-way communication systems shall provide communication between each required location and the fire command center or a central control point location approved by the fire department. Where the central control point is not a constantly attended location, a two-way communication system shall have a timed automatic telephone dial-out capability to a monitoring location. The two-way communication system shall include both audible and visible signals. The two-way communication system shall have a battery backup or an approved alternate source of power that is capable of 90 minutes use upon failure of the normal power source.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-1009, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-1009, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1009, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1010 Doors, gates and turnstiles.

1010.1.9.4 Locks and latches. Locks and latches shall be permitted to prevent operation of doors where any of the following exists:

1. Places of detention or restraint.

2. In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M, and S, and in places of religious worship, the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided:

2.1. The locking device is readily distinguishable as locked;

2.2. A readily visible sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED. The sign shall be in letters 1 inch (25 mm) high on a contrasting background; and

2.3. The use of the key-operated locking device is revocable by the building official for due cause.

3. Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts has no doorknob or surface-mounted hardware.

4. Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt, or security chain, provided such devices are openable from the inside without the use of a key or a tool.

5. Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures.

6. Approved, listed locks without delayed egress shall be permitted in Group I-1 condition 2 assisted living facilities licensed under chapter 388-78A WAC and Group I-1 Condition 2 residential treatment facilities licensed under chapter 246-337 WAC by the state of Washington, provided that:

6.1. The clinical needs of one or more patients require specialized security measures for their safety.

6.2. The doors unlock upon actuation of the automatic sprinkler system or automatic fire detection system.

6.3. The doors unlock upon loss of electrical power controlling the lock or lock mechanism.

6.4. The lock shall be capable of being deactivated by a signal from a switch located in an approved location.

6.5. There is a system, such as a keypad and code, in place that allows visitors, staff persons and appropriate residents to exit. Instructions for exiting shall be posted within six feet of the door.

6.6. Emergency lighting shall be provided at the door.

1010.1.9.7 Controlled egress doors in Groups I-1 and I-2. Electric locking systems, including electromechanical locking systems and electromagnetic locking systems, shall be permitted to be locked in the means of egress in Group I-1 or I-2 occupancies where the clinical needs of persons receiving care require their containment. Controlled egress doors shall be permitted in such occupancies where the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or an approved automatic smoke or heat detection system installed in accordance with Section 907, provided that the doors are installed and operate in accordance with all of the following:

1. The doors unlock upon actuation of the automatic sprinkler system or automatic fire detection system.

2. The doors unlock upon loss of power controlling the lock or lock mechanism.

3. The door locking system shall be installed to have the capability of being unlocked by a switch located at the fire command center, a nursing station or other approved location. The switch shall directly break power to the lock.

4. A building occupant shall not be required to pass through more than one door equipped with a controlled egress locking system before entering an exit.

5. The procedures for unlocking the doors shall be described and approved as part of the emergency planning and preparedness required by Chapter 4 of the *International Fire Code*.

6. There is a system, such as a keypad and code, in place that allows visitors, staff persons and appropriate residents to exit. Instructions for exiting shall be posted within six feet of the door.

7. All clinical staff shall have the keys, codes or other means necessary to operate the locking systems.

8. Emergency lighting shall be provided at the door.

9. The door locking system units shall be listed in accordance with UL 294.

EXCEPTIONS:

1. Items 1 through 4 and 6 shall not apply to doors to areas where persons, which because of clinical needs, require restraint or containment as part of the function of a psychiatric treatment area.
2. Items 1 through 4 and 6 shall not apply to doors to areas where a listed egress control system is utilized to reduce the risk of child abduction from nursery and obstetric areas of a Group I-2 hospital.

1010.1.10 Panic and fire exit hardware. Swinging doors serving a Group H occupancy and swinging doors serving rooms or spaces with an occupant load of 50 or more in a Group A or E occupancy shall not be provided with a latch or lock other than panic hardware or fire exit hardware.

EXCEPTIONS:

1. A main exit of a Group A occupancy shall have locking devices in accordance with Section 1010.1.9.4, Item 2.
2. Doors provided with panic hardware serving a Group A or E occupancy shall be permitted to be electromagnetically locked in accordance with Section 1010.1.9.10.

1010.1.10.3 Electrical rooms and working clearances. Exit and exit access doors serving electrical rooms and working spaces shall swing in the direction of egress travel and shall be equipped with panic hardware or fire exit hardware where such rooms or working spaces contain one or more of the following:

1. Equipment operating at more than 600 volts, nominal.

2. Equipment operating at 600 volts or less, nominal and rated at 800 amperes or more, and where the equipment contains overcurrent devices, switching devices or control devices.

EXCEPTION:

Panic and fire exit hardware is not required on exit and exit access doors serving electrical equipment rooms and working spaces where such doors are not less than twenty-five feet (7.6 m) from the nearest edge of the electrical equipment.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-1010, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-1010, filed 11/27/19, effective 7/1/20; WSR 16-03-055, § 51-54A-1010, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1010, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1011 Stairways.

1011.17 Stairways in individual dwelling units. Stairs or ladders within an individual dwelling unit used for access to areas of 200 square feet (18.6 m²) or less, and not containing the primary bathroom or kitchen, are exempt from the requirements of Section 1009.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1011, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1012 Ramps.

1012.1 Scope. The provisions of this section shall apply to ramps used as a component of a means of egress.

EXCEPTIONS:

1. Other than ramps that are part of the accessible routes providing access in accordance with Sections 1108.2 through 1108.2.4 and 1108.2.6, ramped aisles within assembly rooms or spaces shall conform with the provisions in Section 1029.13.
2. Curb ramps shall comply with ICC A117.1.
3. Vehicle ramps in parking garages for pedestrian exit access shall not be required to comply with Sections 1010.4 through 1010.10 when they are not an accessible route serving accessible parking spaces or other required accessible elements.
4. In a parking garage where one accessible means of egress serving accessible parking spaces or other accessible elements is provided, a second accessible means of egress serving that area may include a vehicle ramp that does not comply with Sections 1010.5, 1010.6, and 1010.9. A landing complying with Sections 1010.7.1 and 1010.7.4 shall be provided at any change of direction in the accessible means of egress.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1012, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1018 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1018, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1018, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1020 Corridors.

1020.5 Air movement in corridors. Corridors shall not serve as supply, return, exhaust, relief or ventilation air ducts.

EXCEPTIONS:

1. Use of a corridor as a source of makeup air for exhaust systems in rooms that open directly onto such corridors, including toilet rooms, bathrooms, dressing rooms, smoking lounges and janitor closets, shall be permitted provided that each such corridor is directly supplied with outdoor air at a rate greater than the rate of makeup air taken from the corridor.
2. Where located within a dwelling unit, the use of corridors for conveying return air shall not be prohibited.
3. Where located within tenant spaces of one thousand square feet (93 m²) or less in area, utilization of corridors for conveying return air is permitted.
4. Incidental air movement from pressurized rooms within health care facilities, provided that a corridor is not the primary source of supply or return to the room.
5. Where such air is part of an engineered smoke control system.
6. Air supplied to corridors serving residential occupancies shall not be considered as providing ventilation air to the dwelling units subject to the following:
 - 6.1. The air supplied to the corridor is one hundred percent outside air; and
 - 6.2. The units served by the corridor have conforming ventilation air independent of the air supplied to the corridor; and
 - 6.3. For other than high-rise buildings, the supply fan will automatically shut off upon activation of corridor smoke detectors which shall be spaced at no more than thirty feet (9144 mm) on center along the corridor; or
 - 6.4. For high-rise buildings, corridor smoke detector activation will close required smoke/fire dampers at the supply inlet to the corridor at the floor receiving the alarm.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1020, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1021 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1021, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1021, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1028 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-1028, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-1028, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1030 Reserved.

[Statutory Authority: Chapter 19.27 RCW. WSR 17-10-023, § 51-54A-1030, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1030, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1103 Fire safety requirements for existing buildings.

1103.4.3 More than five stories. In other than Group I occupancies, interior vertical openings connecting more than five stories shall be protected by fire-resistant and smoke-rated construction.

EXCEPTIONS: 1. Vertical opening protection is not required for Group R-3 occupancies.
2. Vertical opening protection is not required for open parking garages and ramps.
3. Vertical opening protection for escalators shall be in accordance with Section 1103.4.8.

1103.5.5 Nightclub. An automatic sprinkler system shall be provided throughout A-2 nightclubs as defined in this code. No building shall be constructed for, used for, or converted to occupancy as a nightclub except in accordance with this section.

1103.9 Carbon monoxide alarms. Existing Group I or Group R occupancies shall be provided with single station carbon monoxide alarms in accordance with Section 915.4.3. An inspection will occur when alterations, repairs or additions requiring a permit occur, or when one or more sleeping rooms are added or created. The carbon monoxide alarms shall be listed as complying with UL 2034 and be installed and maintained in accordance with NFPA 720-2015 and the manufacturer's instructions.

EXCEPTIONS: 1. For other than R-2 occupancies, if the building does not contain a fuel-burning appliance, a fuel-burning fireplace, or an attached garage.
2. Work involving the exterior surfaces of dwellings, such as the replacement of roofing or siding, or the addition or replacement of windows or doors, or the addition of a porch or deck, or electrical permits.
3. Installation, alteration or repairs of noncombustion plumbing or mechanical systems.
4. Sleeping units or dwelling units in I and R-1 occupancies and R-2 college dormitories, hotel, DOC prisons and work releases and assisted living facilities and residential treatment facilities licensed by the state of Washington which do not themselves contain a fuel-burning appliance, a fuel-burning fireplace, or have an attached garage, need not be provided with carbon monoxide alarms provided that:
4.1. The sleeping units or dwelling unit is not adjacent to any room which contains a fuel-burning appliance, a fuel-burning fireplace, or an attached garage; and
4.2. The sleeping units or dwelling unit is not connected by duct work or ventilation shafts with a supply or return register in the same room to any room containing a fuel-burning appliance, a fuel-burning fireplace, or to an attached garage; and
4.3. The building is provided with a common area carbon monoxide detection system.
5. An open parking garage, as defined in the International Building Code, or enclosed parking garage ventilated in accordance with Section 404 of the International Mechanical Code shall not be considered an attached garage.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1103, filed 1/16/16, effective 7/1/16. Statutory Authority: Chapters 19.27, 19.27A, and 34.05 RCW. WSR 13-24-017, § 51-54A-1103, filed 11/21/13, effective 4/1/14. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1103, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1104 Means of egress for existing buildings.

1104.1 General. Means of egress in existing buildings shall comply with Section 1030 and 1104.2 through 1104.25.

EXCEPTION: Means of egress conforming to the requirements of the building code under which they were constructed and Section 1030 shall not be required to comply with 1104.2 through 1104.22 and 1104.25.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-05-065, § 51-54A-1104, filed 2/12/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-1104, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-1105 Construction requirements for existing Group I-2.

1105.1 General. This section shall be applied by jurisdictions conducting surveys for compliance with the federal centers for medicare and medicaid reimbursement program. Existing Group I-2 shall meet all of the following requirements:

1. The minimum fire safety requirements in Section 1103.
2. The minimum means of egress requirements in Section 1104.
3. The additional egress and construction requirements in Section 1105.

Where the provisions of this chapter conflict with the construction requirements that applied at the time of construction, the most restrictive provisions shall apply.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-1105, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-1204 Section 1204—Solar photovoltaic power systems.

1204.1 General. Installation, modification, or alteration of solar photovoltaic power systems shall comply with this section. Due to the emerging technologies in the solar photovoltaic industry, it is understood fire code officials may need to amend prescriptive requirements of this section to meet the requirements for firefighter access and product installations. Section 104.9 Alternative materials and methods of this code shall be considered when approving the installation of solar photovoltaic power systems. Solar photovoltaic power systems shall be installed in accordance with Sections 605.11.1 through 605.11.2, the *International Building Code* and chapter 19.28 RCW.

1204.2.1 Solar photovoltaic systems for Group R-3 residential and buildings built under the *International Residential Code*. Solar photovoltaic systems for Group R-3 residential and buildings built under the *International Residential Code* shall comply with Sections 1204.2.1.1 through 1204.2.1.3.

- EXCEPTIONS:
1. Residential dwellings with an approved automatic fire sprinkler system installed.
 2. Residential dwellings with approved mechanical or passive ventilation systems.
 3. Where the fire code official determines that the slope of the roof is too steep for emergency access.
 4. Where the fire code official determines that vertical ventilation tactics will not be utilized.
 5. These requirements shall not apply to roofs where the total combined area of the solar array does not exceed thirty-three percent as measured in plan view of the total roof area of the structure, where the solar array will measure 1,000 sq. ft. or less in area, and where a minimum eighteen inches unobstructed pathway shall be maintained along each side of any horizontal ridge.

1204.6 Size of solar photovoltaic array.

1. Each photovoltaic array shall be limited to 150 feet (45,720 mm) by 150 feet (45,720 mm). Multiple arrays shall be separated by a 3-foot wide (914 mm) clear access pathway.

2. Panels/modules shall be located up to the roof ridge where an alternative ventilation method approved by the fire code official has determined vertical ventilation techniques will not be employed.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-1204, filed 1/20/21, effective 2/20/21; WSR 20-01-162, § 51-54A-1204, filed 12/18/19, effective 7/1/20.]

WAC 51-54A-3103 Temporary tents and membrane structures.

3103.5 Use period. Temporary tents, air-supported, air-inflated or tensioned membrane structures are permitted to be erected for a period of less than 180 days within a 12-month period on a single premises. Such structures erected for 180 days or more within a 12-month period shall comply with the IBC.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-3103, filed 1/16/16, effective 7/1/16.]

WAC 51-54A-3304 Precautions against fire.

3304.5.1 Fire watch during construction. Where required by the fire code official, a fire watch shall be provided during nonworking hours for new construction that exceeds 40 feet (12,192 mm) in height above the lowest adjacent grade.

EXCEPTIONS: 1. New construction that is built under the IRC.
2. New construction less than 5 stories and 50,000 square feet per story.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-3304, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-3308 Owner's responsibility for fire protection.

3308.9 Fire safety requirements for buildings of Types IV-A, IV-B, and IV-C construction. Buildings of Types IV-A, IV-B, and IV-C construction designed to be greater than six stories above grade plane shall meet the following requirements during construction unless otherwise approved by the fire code official.

1. Standpipes shall be provided in accordance with Section 3313.
2. A water supply for fire department operations, as approved by the fire code official and the fire chief.
3. Where building construction exceeds six stories above grade plane, at least one layer of noncombustible protection where required by Section 602.4 of the *International Building Code* shall be installed on all building elements more than four floor levels, including mezzanines, below active mass timber construction before erecting additional floor levels.

EXCEPTION: Shafts and vertical exit enclosures shall not be considered a part of the active mass timber construction.

4. Where building construction exceeds six stories above grade plane required exterior wall coverings shall be installed on all floor levels more than four floor levels, including mezzanines, below active mass timber construction before erecting additional floor level.

EXCEPTION: Shafts and vertical exit enclosures shall not be considered a part of the active mass timber construction.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-3308, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-3308, filed 1/2/19, effective 7/1/19.]

WAC 51-54A-3601 Marinas—Scope.

3601.3 Permits. For permits to operate marine motor fuel-dispensing stations, application of flammable or combustible finishes, and hot works, see Section 105.6.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-3601, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-3601, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-3602 Definitions.

3602.1 Definitions. The following terms are defined in Chapter 2:

COVERED BOAT MOORAGE

FLOAT

GRAVITY-OPERATED DROP OUT VENTS

MARINA

PIER

VESSEL

WHARF

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-3602, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-3604 Fire protection equipment.

3604.2 Standpipes. Marinas shall be equipped throughout with Class I manual, dry standpipe systems in accordance with NFPA 303. Systems shall be provided with outlets located such that no point on the marina pier or float system exceeds 150 feet from a standpipe outlet.

3604.3 Access and water supply. Piers and wharves shall be provided with fire apparatus access roads and water-supply systems with on-site fire hydrants when required and approved by the fire code official. At least one fire hydrant capable of providing the required fire flow shall be provided within an approved distance of standpipe supply connections.

3604.4 Portable fire extinguishers. One 4A40BC fire extinguisher shall be provided at each standpipe outlet. Additional fire extinguishers, suitable for the hazards involved, shall be provided and maintained in accordance with Section 906.

3604.7 Smoke and heat vents. Approved automatic smoke and heat vents shall be provided in covered boat moorage areas exceeding 2,500 sq. ft. (232 m²) in area, excluding roof overhangs.

EXCEPTION: Smoke and heat vents are not required in areas protected by automatic sprinklers.

3604.7.1 Design and installation. Where smoke and heat vents are required they shall be installed near the roof peak, evenly distributed and arranged so that at least one vent is over each covered berth. The effective vent area shall be calculated using a ratio of one square foot of vent to every fifteen square feet of covered berth area (1:15). Each vent shall provide a minimum opening size of 4 ft. x 4 ft.

3604.7.1.1 Smoke and heat vents. Smoke and heat vents shall operate automatically by actuation of a heat-responsive device rated at 100°F (56°C) above ambient.

EXCEPTION: Gravity-operated drop out vents.

3604.7.1.2 Gravity-operated drop out vents. Gravity-operated drop out vents shall fully open within 5 minutes after the vent cavity is exposed to a simulated fire represented by a time-temperature gradient that reaches an air temperature of 500°F (260°C) within 5 minutes.

3604.8 Draft curtains. Draft curtains shall be provided in covered boat moorage areas exceeding 2,500 sq. ft. (232 m²) in area, excluding roof overhangs.

EXCEPTION: Draft curtains are not required in areas protected by automatic sprinklers.

3604.8.1 Draft curtain construction. Draft curtains shall be constructed of sheet metal, gypsum board or other approved materials that provide equivalent performance to resist the passage of smoke. Joints and connections shall be smoke tight.

3604.8.2 Draft curtain location and depth. The maximum area protected by draft curtains shall not exceed 2,000 sq. ft. (186 m²) or two slips or berths, whichever is smaller. Draft curtains shall not extend past the piling line. Draft curtains shall have a minimum depth of 4 feet and shall not extend closer than 8 feet (2438 mm) to the walking surface of the pier.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-3604, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-3800 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-3800, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-3800, filed 11/27/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW. WSR 17-03-104, § 51-54A-3800, filed 1/17/17, effective 5/1/17.]

WAC 51-54A-3900 Marijuana processing or extraction facilities.

SECTION 3901—ADMINISTRATION

3901.1 Scope. Facilities used for marijuana processing or extraction that utilize chemicals or equipment as regulated by the International

Fire Code shall comply with this chapter and the International Building Code. The extraction process includes the act of extraction of the oils and fats by use of a solvent, desolventizing of the raw material and production of the miscella, distillation of the solvent from the miscella and solvent recovery. The use, storage, transfilling, and handling of hazardous materials in these facilities shall comply with this chapter and the International Building Code.

3901.2 Application. The requirements set forth in this chapter are requirements specific only to marijuana processing and extraction facilities and shall be applied as exceptions or additions to applicable requirements set forth elsewhere in this code.

3901.2.1 For the purposes of this chapter, marijuana processing and extraction shall be limited to those processes and extraction methods that utilize chemicals defined as hazardous by the International Fire Code and are regulated as such. Such processes and extraction methods shall meet the requirements of this chapter and other applicable requirements elsewhere in this code and its referenced standards.

EXCEPTION: Provisions of WAC 314-55-104 do not apply to this chapter.

3901.2.2 The use of equipment regulated by the International Fire Code for either marijuana processing or marijuana extraction shall meet the requirements of this chapter and other applicable requirements elsewhere in this code.

3901.3 Multiple hazards. Where a material, its use or the process it is associated with poses multiple hazards, all hazards shall be addressed in accordance with Section 5001.1 and other material specific chapters.

3901.4 Existing buildings or facilities. Existing buildings or facilities used for the processing of marijuana shall comply with this chapter.

3901.5 Permits. Permits shall be required as set forth in Section 105.6 and 105.7.

SECTION 3902—DEFINITIONS

Desolventizing. The act of removing a solvent from a material.

Finding. The results of an inspection, examination, analysis or review.

Marijuana processing. Processing that uses chemicals or equipment as regulated by the International Fire Code; this does not include the harvesting, trimming, or packaging of the plant.

Miscella. A mixture, in any proportion, of the extracted oil or fat and the extracting solvent.

Observation. A practice or condition not technically noncompliant with other regulations or requirements, but could lead to noncompliance if left unaddressed.

Transfilling. The process of taking a gas source, either compressed or in liquid form (usually in bulk containers), and transferring it into a different container (usually a smaller compressed cylinder).

SECTION 3903—PROCESSING OR EXTRACTION OF MARIJUANA

3903.1 Location. Marijuana processing shall be located in a building complying with the International Building Code and this code. Require-

ments applied to the building shall be based upon the specific needs for mitigation of the specific hazards identified.

3903.2 Systems, equipment, and processes. Systems, equipment, and processes shall be in accordance with Sections 3903.2.1 through 3903.2.7. In addition to the requirements of this chapter, electrical equipment shall be listed or evaluated for electrical fire and shock hazard in accordance with RCW 19.28.010(1).

3903.2.1 Application. Systems, equipment, and processes shall include, but are not limited to, vessels, chambers, containers, cylinders, tanks, piping, tubing, valves, fittings, and pumps.

3903.2.2 General requirements. In addition to the requirements in Section 3903, systems, equipment, and processes shall also comply with Section 5003.2, other applicable provisions of this code, the International Building Code, and the International Mechanical Code. The use of ovens in post-process purification or winterization shall comply with Section 3903.2.7.

3903.2.3 Systems and equipment. Systems or equipment used for the extraction of oils from plant material shall be listed and approved for the specific use. If the system used for extraction of oils and products from plant material is not listed, then a technical report prepared by a Washington licensed engineer shall be provided to the code official for review and approval.

3903.2.4 Change of extraction medium. Where the medium of extraction or solvent is changed from the material indicated in the technical report, or as required by the manufacturer, the technical report shall be revised at the cost of the facility owner, and submitted for review and approval by the fire code official prior to the use of the equipment with the new medium or solvent.

3903.2.5 Required technical report. The technical report documenting the equipment design shall be submitted for review and approval by the fire code official prior to the equipment being installed at the facility.

3903.2.5.1 Content of technical report and engineering analysis. All, but not limited to, the items listed below shall be included in the technical report.

1. Manufacturer information.
2. Engineer of record information.
3. Date of review and report revision history.
4. Signature page shall include:
 - 4.1 Author of the report;
 - 4.2 Date of report; and
 - 4.3 Seal, date and signature of engineer of record performing the design.
5. Model number of the item evaluated. If the equipment is provided with a serial number, the serial number shall be included for verification at the time of site inspection.
6. Methodology of the design review process used to determine minimum safety requirements. Methodology shall consider the basis of design, and shall include a code analysis and code path to demonstrate the reason why specific codes or standards are applicable or not.
7. Equipment description. A list of all components and subassemblies of the system or equipment, indicating the material, solvent compatibility, maximum temperature and pressure limits.

8. A general flow schematic or general process flow diagram (PFD) of the process, including maximum temperatures, pressures and solvent state of matter shall be identified in each step or component. It shall provide maximum operating temperature and pressure in the system.

9. Analysis of the vessel(s) if pressurized beyond standard atmospheric pressure. Analysis shall include purchased and fabricated components.

10. Structural analysis for the frame system supporting the equipment.

11. Process safety analysis of the extraction system, from the introduction of raw product to the end of the extraction process.

12. Comprehensive process hazard analysis considering failure modes and points of failure throughout the process. This portion of the review should include review of emergency procedure information provided by the manufacturer of the equipment or process and not that of the facility, building or room.

13. Review of the assembly instructions, operational and maintenance manuals provided by the manufacturer.

14. Report shall include findings and observations of the analysis.

15. List of references used in the analysis.

3903.2.6 Building analysis. The technical report, provided by the engineer of record, shall include a review of the construction documents for location, room, space or building and include recommendations to the fire code official.

3903.2.6.1 Site inspection. The engineer of record of the equipment shall inspect the installation of the extraction equipment for conformance with the technical report and provide documentation to the fire code official that the equipment was installed in conformance with the approved design.

3903.2.7 Post-process purification and winterization. Post-processing and winterization involving the heating or pressurizing of the miscella shall be approved and performed in an appliance listed for such use. Domestic or commercial cooking appliances shall not be used. The use of industrial ovens shall comply with Chapter 30.

EXCEPTION: An automatic fire extinguishing system shall not be required for batch-type Class A ovens having less than 3.0 cubic feet of work space.

3903.3 Construction requirements.

3903.3.1 Location. Marijuana extraction shall not be located in any building containing a Group A, E, I or R occupancy.

3903.3.1.1 Extraction room. The extraction equipment and processes utilizing hydrocarbon solvents shall be located in a room or area dedicated to extraction.

3903.3.2 Egress. Doors installed on rooms or areas dedicated to extraction shall be equipped with panic hardware or fire exit hardware.

3903.3.2.1 Facility egress. Egress requirements shall be in compliance with Chapter 10 of the International Building Code.

3903.3.3 Ventilation. Ventilation shall be provided in compliance with Chapter 4 of the International Mechanical Code.

3903.3.4 Control area. Control areas shall comply with Section 5003.8.3.

3903.3.5 Ignition source control. Extraction equipment and processes using flammable or combustible gas or liquid solvents shall be provided with ventilation rates for the room to maintain the concentration of flammable constituents in air below 25 percent of the lower flammability limit of the respective solvent. If not provided with the required ventilation rate, Class I Division II electrical requirements shall apply to the entire room.

3903.3.6 Interlocks. When a hazardous exhaust system is provided, all electrical components within the extraction room or area shall be interlocked with the hazardous exhaust system, and when provided, the gas detection system. When the hazardous exhaust system is not operational, then light switches and electrical outlets shall be disabled. Activation of the gas detection system shall disable all light switches and electrical outlets.

3903.3.7 Emergency power.

3903.3.7.1 Emergency power for extraction process. Where power is required for the operation of the extraction process, an automatic emergency power source in accordance with Section 5004.7 and 604 shall be provided. The emergency power source shall have sufficient capacity to allow safe shutdown of the extraction process plus an additional 2 hours of capacity beyond the shutdown process.

3903.3.7.2 Emergency power for other than extraction process. An automatic emergency power system in accordance with Section 604 shall be provided when any of the following items are installed:

1. Extraction room lighting;
2. Extraction room ventilation system;
3. Solvent gas detection system;
4. Emergency alarm systems;
5. Automatic fire extinguishing systems.

3903.3.8 Continuous gas detection system. For extraction processes utilizing gaseous hydrocarbon-based solvents, a continuous gas detection system shall be provided. The gas detection threshold shall not exceed 25 percent of the LEL/LFL limit of the materials.

3903.4 Carbon dioxide enrichment or extraction. Extraction processes using carbon dioxide shall comply with this section.

3903.4.1 Scope. Carbon dioxide systems with more than 100 pounds of carbon dioxide shall comply with Sections 3903.4 through 3903.4.3. This section is applicable to carbon dioxide systems utilizing compressed gas systems, liquefied-gas systems, dry ice, or on-site carbon dioxide generation.

3903.4.2 Permits. Permits shall be required as set forth in Sections 105.6 and 105.7.

3903.4.3 Signage. At the entrance to each area using or storing carbon dioxide, signage shall be posted indicating the hazard. Signs shall be durable and permanent in nature and not less than 7 inches wide by 10 inches tall. Signs shall bear the warning "DANGER! POTENTIAL OXYGEN DEFICIENT ATMOSPHERE." NFPA 704 signage shall be provided at the building main entry and the rooms where the carbon dioxide is used and stored.

3903.5 Flammable or combustible liquid. The use of a flammable or combustible liquid for the extraction of oils and fats from marijuana shall comply with this section.

3903.5.1 Scope. The use of flammable and combustible liquids for liquid extraction processes where the liquid is boiled, distilled, or evaporated shall comply with this section and NFPA 30.

3903.5.2 Location. The process using a flammable or combustible liquid shall be located within a hazardous exhaust fume hood, rated for exhausting flammable vapors. Electrical equipment used within the hazardous exhaust fume hood shall be listed or approved for use in flammable atmospheres. Heating of flammable or combustible liquids over an open flame is prohibited.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-3900, filed 1/20/21, effective 2/20/21. Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-3900, filed 1/2/19, effective 7/1/19.]

WAC 51-54A-3904 Systems and equipment.

Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-3904, filed 1/20/21, effective 2/20/21; WSR 19-24-058, § 51-54A-3904, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-4000 Fixed guideway transit and passenger rail systems.

4001.1 Scope. Fixed guideway transit and passenger rail systems shall be in accordance with NFPA 130.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-4000, filed 1/20/21, effective 2/20/21.]

WAC 51-54A-5003 General requirements.

**Table 5003.11.1
Maximum Allowable Quantities Per Indoor and Outdoor Control Area in Group M and S Occupancies - Nonflammable Solids, Nonflammable and Combustible Liquids^{d,e,f}**

| Conditions | | Maximum Allowable Quantities Per Control Area | |
|--|----------------|---|-------------------|
| Materials | Class | Solids (pounds) | Liquids (gallons) |
| A. Health-Hazard Materials Nonflammable and Noncombustible Solids and Liquids | | | |
| 1. Corrosive ^{b,c} | Not Applicable | 9,750 | 975 |
| 2. Highly Toxic | Not Applicable | 20 ^{b,c} | 2 ^{b,c} |
| 3. Toxics ^{b,c} | Not Applicable | 1,000 | 100 |

| Conditions | | Maximum Allowable Quantities Per Control Area | |
|--|------------------|---|---------------------|
| | | Solids (pounds) | Liquids (gallons) |
| Materials | Class | | |
| B. Physical-Hazard Materials Nonflammable and Noncombustible Solids and Liquids | | | |
| 1. Oxidizer ^{b,c} | 4 | Not Allowed | Not Allowed |
| | 3 | 1,350 ^g | 135 |
| | 2 | 2,250 ^h | 225 |
| | 1 | 18,000 ^{ij} | 1,800 ^{ij} |
| 2. Unstable (Reactives) ^{b,c} | 4 | Not Allowed | Not Allowed |
| | 3 | 550 | 55 |
| | 2 | 1,150 | 115 |
| | 1 | Not Limited | Not Limited |
| 3. Water Reactives | 3 ^{b,c} | 550 | 55 |
| | 2 ^{b,c} | 1,150 | 115 |
| | 1 | Not Limited | Not Limited |

For SI: 1 pound = 0.454 kg, 1 gallon = 3.785 L, 1 cubic foot = 0.02832 m³.

- a. Hazard categories are as specified in Section 5001.2.2.
- b. Maximum allowable quantities shall be increased 100 percent in buildings equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1. Where note c applies, the increase for both notes shall be applied accumulatively.
- c. Maximum allowable quantities shall be increased 100 percent where stored in approved storage cabinets in accordance with Section 5003.8. Where note b applies, the increase for both notes shall be applied accumulatively.
- d. See Table 5003.8.3.2 for design and number of control areas.
- e. Maximum allowable quantities for other hazardous material categories shall be in accordance with Section 5003.1.
- f. Maximum allowable quantities shall be increased 100 percent in outdoor control areas.
- g. Maximum allowable quantities shall be increased to 2,250 pounds where individual packages are in the original sealed containers from the manufacturer or packager and do not exceed 10 pounds each.
- h. Maximum allowable quantities shall be increased to 4,500 pounds where individual packages are in the original sealed containers from the manufacturer or packager and do not exceed 10 pounds each.
- i. Quantities are unlimited where protected by an automatic sprinkler system.
- j. Quantities are unlimited in an outdoor control area.
- k. Maximum allowable quantity of consumer products shall be increased to 10,000 pounds where individual packages are in original sealed containers from the manufacturer and the toxic classification is exclusively based on the LC₅₀.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-5003, filed 11/27/19, effective 7/1/20.]

WAC 51-54A-5306 Medical gas systems.

5306.1 General. Compressed gases at hospitals and similar facilities intended for inhalation or sedation including, but not limited to, analgesia systems for dentistry, podiatry, veterinary and similar uses shall comply with Sections 5306.2 through 5306.4 in addition to other requirements of this chapter.

EXCEPTION: All new distribution piping, supply manifolds, connections, regulators, valves, alarms, sensors and associated equipment shall be in accordance with the Plumbing Code.

5306.5 Medical gas systems. The maintenance and testing of medical gas systems including, but not limited to, distribution piping, supply manifolds, connections, pressure regulators and relief devices and valves, shall comply with the maintenance and testing requirements of NFPA 99 and the general provisions of this chapter.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-5306, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-5306, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-5307 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-5307, filed 12/18/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-5307, filed 4/25/17, effective 5/26/17.]

WAC 51-54A-5601 General.

5601.1 Scope. The provisions of this chapter shall govern the possession, manufacture, storage, handling, sale and use of explosives, explosive materials, and small arms ammunition. The manufacture, storage, handling, sale and use of fireworks shall be governed by chapter 70.77 RCW, and by chapter 212-17 WAC and local ordinances consistent with chapter 212-17 WAC.

EXCEPTIONS:

1. The Armed Forces of the United States, Coast Guard or National Guard.
2. Explosives in forms prescribed by the official United States Pharmacopoeia.
3. The possession, storage and use of small arms ammunition when packaged in accordance with DOT packaging requirements.
4. The possession, storage and use of not more than 1 pound (0.454 kg) of commercially manufactured sporting black powder, 20 pounds (9 kg) of smokeless powder and 10,000 small arms primers for hand loading of small arms ammunition for personal consumption.
5. The use of explosive materials by federal, state and local regulatory, law enforcement and fire agencies acting in their official capacities.
6. Special industrial explosive devices which in the aggregate contain less than 50 pounds (23 kg) of explosive materials.
7. The possession, storage and use of blank industrial-power load cartridges when packaged in accordance with DOT packaging regulations.
8. Transportation in accordance with DOT 49 C.F.R. Parts 100-185.
9. Items preempted by federal regulations.

5601.1.1 Explosive material standard. In addition to the requirements of this chapter, NFPA 495 shall govern the manufacture, transportation, storage, sale, handling and use of explosive materials. See also chapter 70.74 RCW and chapter 296-52 WAC.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-5601, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-5601, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-5704 Storage.

5704.2.11 Underground tanks. Underground storage of flammable and combustible liquids in tanks shall comply with Section 5704.2 and Sections 5704.2.11.1 through 5704.2.11.4.2. Corrosion protection shall comply with WAC 173-360-305.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-5704, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-5704, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-5706 Special operations.

5706.5.4.5 Commercial, industrial, governmental or manufacturing. Dispensing of Class II and III motor vehicle fuel from tank vehicles into the fuel tanks of motor vehicles located at commercial, industrial, governmental or manufacturing establishments is allowed where permitted, provided such dispensing operations are conducted in accordance with the following: (Those sections not noted here remain unchanged.)

12. Fuel delivery vehicles shall be equipped with spill clean-up supplies in accordance with the department of ecology's Source Control Best Management Practices. Such supplies shall be readily available for deployment by the operator at all times and include nonwater absorbents capable of absorbing 15 gallons (56.76 L) of diesel fuel, storm drain plug or cover kit, a nonwater absorbent containment boom of a minimum 10 foot long (3038 mm) length with a 12-gallon (45.41 L) absorbent capacity, a nonmetallic shovel, and two 5-gallon (19 L) buckets with lids.

[Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-5706, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-5707 Section 5705—On-demand mobile fueling operations. 5707.1 General. On-demand mobile fueling operations that dispense Class I, II and III liquids into the fuel tanks of motor vehicles shall comply with Sections 5707.1 through 5707.6.6.

EXCEPTION: Fueling from an *approved* portable container in cases of an emergency or for personal use.

5707.1.1 Approval required. Mobile fueling operations shall not be conducted without first obtaining a *permit* and approval from the fire code official. Mobile fueling operations shall occur only at *approved* locations. The fire code official is authorized to *approve* individual locations or geographic areas where mobile fueling is allowed.

5707.1.2 Coordination of permits. *Permits* across multiple authorities having jurisdiction shall be coordinated in accordance with Sections 5707.1.2.1 through 5707.1.2.4.

5707.1.2.1 Acceptance of permits issued by other authorities having jurisdiction. Local authorities having jurisdiction that allow mobile on demand fueling trucks may accept conforming *permits* issued and/or inspections performed by any other local authorities having jurisdiction in Washington state. Local authorities having jurisdiction that choose to accept conforming *permits* issued by other local authorities having jurisdiction in Washington state retain the right to enforce the provisions of this section.

5707.1.2.2 Local authorities having jurisdiction not offering operator or truck certification. A conforming operator or vehicle *permit* issued by one local authority having jurisdiction shall be recognized and accepted by all local authorities having jurisdiction in Washington

state, if those local authority having jurisdictions allow mobile on-demand fueling and do not offer such operator or truck certification. Under no circumstances will an issuing local authority having jurisdiction be expected to perform permissive inspections beyond their jurisdiction.

5707.1.2.3 Commencing permit issuance. When a local authority having jurisdiction that has previously authorized mobile fueling operations but not issued their own *permits* commences *permit* issuance for mobile fueling operations or vehicles, that local authority having jurisdiction shall continue to accept *permits* previously issued by another local authority having jurisdiction in Washington state for three months or until their expiration date, whichever is sooner.

5707.1.2.4 Permit record maintenance. Issuing local authorities having jurisdiction shall maintain a publicly available list of current *permits* or other information source to enable all parties to have information about whether *permits* are in good standing.

5707.2 Mobile fueling vehicle. An on-demand mobile fueling vehicle shall be utilized in on-demand fueling operations for the dispensing of Class I, II or III liquids into the fuel tanks of motor vehicles and shall comply with Sections 5707.2.1 and 5707.2.2.

5707.2.1 Mobile fueling vehicle classifications. An on-demand mobile fueling vehicle shall be classified as one of the following:

1. **Type 1** Mobile Fueling Vehicle - A tank vehicle that complies with NFPA 385 and that has chassis-mounted tanks where the aggregate capacity does not exceed 1600 gallons (6057 L).

2. **Type 2** Mobile Fueling Vehicle - A vehicle with one or more chassis-mounted tanks or chassis-mounted containers, not to exceed 110 gallons (415 L) capacity for each tank or container and having an aggregate capacity not exceeding 800 gallons (3028 L) or the weight capacity of the vehicle in accordance with DOTn.

3. **Type 3** Mobile Fueling Vehicle - A vehicle that carries a maximum aggregate capacity of 60 gallons (227 L) of motor fuel in metal safety cans *listed* in accordance with UL 30 or other *approved* metal containers, each not to exceed 5 gallons (19 L) in capacity.

5707.2.2 Mobile fueling vehicle requirements. Each mobile fueling vehicle shall comply with all local, state and federal requirements, and the following:

1. Mobile fueling vehicles with a chassis-mounted tank in excess of 110 gallons (415 L) shall also comply with the requirements of Section 5706.6 and NFPA 385.

2. The mobile fueling vehicle and its equipment shall be maintained in good repair.

3. Safety cans and *approved* metal containers shall be secured to the mobile fueling vehicle except when in use.

4. Fueling a motor vehicle from tanks or containers mounted in a trailer connected to a mobile fueling vehicle shall be prohibited.

5707.3 Required documents. Documents developed to comply with Sections 5707.3.1 through 5707.3.3 shall be updated as necessary by the owner of the mobile fueling operation and shall be maintained in compliance with Section 108.3.

5707.3.1 Safety and emergency response plan. Mobile fueling operators shall have an *approved* written safety and emergency response plan that establishes policies and procedures for fire safety, spill prevention

and control, personnel training and compliance with other applicable requirements of this code. The safety and emergency response plan shall specifically address and require that all operators assess surroundings prior to fueling to consider the presence of items listed in Section 5707.3.3.

5707.3.2 Training records. Mobile fueling vehicles shall be operated only by designated personnel who are trained on proper fueling procedures and the safety and emergency response plan. Training records of operators shall be maintained.

5707.3.3 Site plan. Where required by the fire code official, a site plan shall be developed for each location or area at which mobile fueling occurs. The site plan shall be in sufficient detail to indicate but not be limited to the following:

1. All buildings, structures.
2. Lot lines or property lines.
3. Electric car chargers.
4. Solar photovoltaic parking lot canopies.
5. Appurtenances on-site and their use or function.
6. All uses adjacent to the lot lines of the site.
7. Fueling locations.
8. Locations of all storm drain openings and adjacent waterways or wetlands.
9. Information regarding slope, natural drainage, curbing, and impounding.
10. How a spill will be kept on the site property.
11. Scale of the site plan.

5707.3.4 Tiered sites. Where a site permitting process is required by the local jurisdiction, a site shall be designated by the fire code official to be one of the following and based on local provisions as necessitated by zoning laws, environmental laws, public safety, and other characteristics.

5707.3.4.1 Tier 1 sites. Sites that do not present atypical geographic, safety or environmental concerns shall be provided expedited permitting review and shall allow *permit* issuance prior to site inspection. The fire code official may impose additional conditions and may perform a site inspection during the period of *permit* validity.

5707.3.4.2 Tier 2 sites. Sites that require an inspection shall be approved by the fire code official prior to *permit* issuance.

5707.4 Mobile fueling areas. During fueling, the mobile fueling vehicle and point of connection of the vehicle being fueled shall not be located on public streets, public ways or inside buildings. Fueling on the roof level of parking structures or other buildings is prohibited.

5707.4.1 Separation. During fueling, the point of connection of the vehicle being fueled shall not take place within 25 feet (7620 mm) of buildings, lot lines, property lines or combustible storage. Mobile fueling vehicles shall not park within 10 feet (3048 mm) of buildings, lot lines, property lines or combustible storage.

- EXCEPTIONS:
1. The fire code official shall be authorized to decrease the separation distance for dispensing from metal safety cans or other *approved* metal containers in accordance with Section 5707.2.
 2. The point of fueling shall not take place within 10 feet (3048 mm) of buildings, lot lines, property lines or combustible storage when the mobile fueling vehicle has an approved vapor recovery system or is servicing vehicles with on board refueling vapor recovery.

Where dispensing operations occur within 15 feet (4572 mm) of a storm drain, an *approved* storm drain cover or an *approved* equivalent method that will prevent any fuel from reaching the drain shall be used.

5707.4.2 Sources of ignition. Smoking, open flames and other sources of ignition shall be prohibited within 25 feet (7620 mm) of fuel dispensing activities. Signs prohibiting smoking or open flames within 25 feet (7620 mm) of the vehicle or the point of fueling shall be prominently posted on the mobile fueling vehicle. The engines of vehicles being fueled shall be shut off during fueling.

5707.4.3 Electrical equipment. Mobile fueling shall not occur within 20 feet of electrical equipment located within 18 inches of the ground unless such electrical equipment is rated for Class 1, Division 2 hazardous locations in accordance with NFPA 70.

5707.5 Equipment. Mobile fueling equipment shall comply with Sections 5707.5.1 through 5707.5.5.

5707.5.1 Dispensing hoses and nozzles. Where equipped, the dispensing hose shall not exceed 50 feet (15240 mm) in length. The dispensing nozzles and hoses shall be of an *approved* and *listed* type. Where metal-to-metal contact cannot be made between the nozzle and the fuel fill opening, then a means for bonding the mobile fueling vehicle to the motor vehicle shall be provided and employed during fueling operations.

5707.5.2 Break-away device. A listed break-away device shall be provided at the nozzle.

EXCEPTION: Mobile fueling vehicles equipped with an approved brake interlock tied to the nozzle holder that prohibits movement of the mobile fueling vehicle when the nozzle is removed from its holder or tied to the delivery of fuel that prevents activation of the pumping system.

5707.5.3 Shut-off valve and fuel limit. Mobile fueling vehicles shall be equipped with a *listed* shut-off valve assembly and a fuel limit switch set to a maximum of 30 gallons (116 L).

5707.5.4 Fire extinguisher. An *approved* portable fire extinguisher complying with Section 906 with a minimum rating of 4A:80-B:C shall be provided on the mobile fueling vehicle with signage clearly indicating its location.

5707.5.5 Spill kit. Mobile fueling vehicles shall contain a minimum 5 gallon (19 L) spill kit of an *approved* type.

5707.6 Operations. Mobile fueling vehicles shall be constantly attended during fueling operations with brakes set and warning lights in operation. Mobile fueling vehicles shall not obstruct emergency vehicle access roads.

5707.6.1 Dispensing hose. Where equipped, mobile fueling vehicles shall be positioned in a manner to preclude traffic from driving over the dispensing hose. The dispensing hose shall be properly placed on an *approved* reel or in an *approved* compartment prior to moving the mobile fueling vehicle.

5707.6.2 Drip control. Operators shall place a drip pan or an absorbent pillow under the nozzle and each fuel fill opening prior to and during dispensing operations to catch drips.

5707.6.3 Safety cones. Safety cones or other visual barriers shall be employed as warning devices to highlight the vehicle fueling area.

Signs prohibiting smoking or open flames within 25 feet (7620 mm) shall be prominently posted in the vehicle fueling area.

5707.6.4 Vehicle lights. The mobile fueling vehicle flasher lights shall be in operation while dispensing operations are in progress.

5707.6.5 Nighttime deliveries. Nighttime deliveries shall only be made in areas adequately lighted per WAC 296-800-21005.

5707.6.6 Spill reporting. Spills shall be reported in accordance with Section 5003.3.1.

[Statutory Authority: RCW 19.27.077, 19.27.031 and 19.27.074. WSR 21-13-023, § 51-54A-5707, filed 6/9/21, effective 7/10/21.]

WAC 51-54A-6108 Fire protection.

6108.1 General. Storage, handling and transportation of liquefied petroleum gas (LP-gas) and the installation of LP-gas equipment pertinent to systems for such uses shall comply with this chapter and NFPA 58. Properties of LP-gas shall be determined in accordance with Appendix B of NFPA 58.

EXCEPTION: The use and storage of listed propane fired barbeque grills on R-2 decks and balconies with an approved container not exceeding a water capacity of 20 pounds (9 kg) that maintain a minimum clearance of 18 inches on all sides, unless listed for lesser clearances.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-6108, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-6108, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-8000 Referenced standards.

| | |
|---|--------|
| NFPA 96-07 Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations | 609.3 |
| NFPA 720-15 Standard for the Installation of Carbon Monoxide (CO) Warning Equipment in Dwelling Units | 1103.9 |
| NFPA 130-17 Standard for Fixed Guideway Transit and Passenger Rail Systems | 3901.1 |

[Statutory Authority: RCW 19.27.031, 19.27.074 and chapter 19.27 RCW. WSR 19-02-086, § 51-54A-8000, filed 1/2/19, effective 7/1/19. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-8000, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-8000, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-8100 Reserved.

[Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-8100, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-8100, filed 2/1/13, effective 7/1/13.]

WAC 51-54A-8200 International Wildland-Urban Interface Code.

101.5 Additions or alterations. Additions or alterations may be made to any building or structure without requiring the existing building or structure to comply with all of the requirements of this code, provided the addition or alteration conforms to that required for a new building or structure.

EXCEPTION: Provisions of this code that specifically apply to existing conditions are retroactive. See Sections 402.3, 601.1 and Appendix A.

Additions or alterations shall not cause the existing building or structure to become unsafe. An unsafe condition shall be deemed to have been created if an addition or alteration will cause the existing building or structure to become structurally unsafe or overloaded; will not provide adequate access in compliance with the provisions of this code or will obstruct existing exits or access; will create a fire hazard; will reduce required fire resistance or will otherwise create conditions dangerous to human life.

108.3 Site plan. In addition to the requirements for plans in the *International Building Code*, the code official may require site plans which include topography, width and percent of grade of access roads, landscape and vegetation details, locations of structures or building envelopes, existing or proposed overhead utilities, occupancy classification of buildings, types of ignition resistant construction of buildings, structures and their appendages, roof classification of buildings, and site water supply systems. The code official is authorized to waive or modify the requirement for a site plan.

108.4 Vegetation management plans. When required by the code official or when utilized by the permit applicant pursuant to Section 502, vegetation management plans shall be prepared and shall be submitted to the code official for review and approval as part of the plans required for a permit. See Appendix B.

108.7 Vicinity plan. When required by the code official, the requirements for site plans shall include details regarding the vicinity within 300 feet (91,440 mm) of property lines, including other structures, slope, vegetation, fuel breaks, water supply systems and access roads.

402.1.1 Access. New subdivisions, as determined by this jurisdiction, shall be provided with fire apparatus access roads in accordance with the *International Fire Code*.

402.1.2 Water supply. New subdivisions, as determined by this jurisdiction, shall be provided with water supply in accordance with the *International Fire Code*.

402.2 Individual structures. Individual structures shall comply with Sections 402.2.1 and 402.2.2.

402.2.1 Access. Individual structures hereafter constructed or relocated into or within wildland-urban interface areas shall be provided with fire apparatus access in accordance with the *International Fire Code*.

402.2.2 Water supply. Individual structures hereafter constructed or relocated into or within wildland-urban interface areas shall be provided with a conforming water supply in accordance with the *International Fire Code*.

EXCEPTIONS: 1. Structures constructed to meet the requirements for the class of ignition-resistant construction specified in Table N503.1 for a nonconforming water supply.
2. Buildings containing only private garages, carports, sheds and agricultural buildings with a floor area of not more than 600 square feet (56 m²).

402.3 Existing conditions. Existing address markers, roads and fire protection equipment shall be in accordance with the *International Fire Code*.

**Table 503.1
Ignition-Resistant Construction^a**

| | Fire Hazard Severity | | | | | |
|------------------|-------------------------------|------------|---------------------------|------------|---------------------------|---------------|
| | Moderate Hazard | | High Hazard | | Extreme Hazard | |
| | Water Supply ^b | | Water Supply ^b | | Water Supply ^b | |
| | Defensible Space ^c | Conforming | Nonconforming | Conforming | Nonconforming | Conforming |
| Nonconforming | IR 2 | IR 1 | IR 1 | IR 1 N.C. | IR 1 N.C. | Not Permitted |
| Conforming | IR 3 | IR 2 | IR 2 | IR 1 | IR 1 | IR 1 N.C. |
| 1.5 x Conforming | Not Required | IR 3 | IR 3 | IR 2 | IR 2 | IR 1 |

^aAccess shall be in accordance with Section 402.

^bWater supply shall be in accordance with Section 402.1.

IR 1 = Ignition-resistant construction in accordance with Section 504.

IR 2 = Ignition-resistant construction in accordance with Section 505.

IR 3 = Ignition-resistant construction in accordance with Section 506.

N.C. = Exterior walls shall have a fire-resistance rating of not less than 1 hour and the exterior surfaces of such walls shall be noncombustible. Usage of log wall construction is allowed.

^cConformance based on Section 603.

403 Access. This section not adopted.

404 Water supply. This section not adopted.

APPENDIX B-VEGETATION MANAGEMENT PLAN - THIS APPENDIX IS ADOPTED.

APPENDIX D-FIRE DANGER RATING SYSTEM - THIS APPENDIX IS ADOPTED.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-8200, filed 12/18/19, effective 7/1/20. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-8200, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-8200, filed 1/16/16, effective 7/1/16.]