

**WAC 212-44-080 Fire alarm.** Every child birth center shall have an electrically supervised manual fire alarm system. Operation of any fire alarm activating device shall automatically, without delay, accomplish general alarm indication and sound an audible alarm throughout the building or affected portion thereof.

[Statutory Authority: RCW 18.46.110. WSR 80-15-077 (Order FM 80-1), § 212-44-080, filed 10/20/80; Order FM-77-3, § 212-44-080, filed 12/8/77.]