

(Effective until March 1, 2022.)

WAC 246-215-05335 Numbers and capacities—Filter, compressed air (2009 FDA Food Code 5-303.11). A filter that does not pass oil or oil vapors must be installed in the air supply line between the compressor and DRINKING WATER system when compressed air is used to pressurize the water tank system.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05335, filed 1/17/13, effective 5/1/13.]

(Effective March 1, 2022.)

WAC 246-215-05335 Numbers and capacities—Filter, compressed air (FDA Food Code 5-303.11). A filter that does not pass oil or oil vapors must be installed in the air supply line between the compressor and DRINKING WATER system when compressed air is used to pressurize the water tank system.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-05335, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-05335, filed 1/17/13, effective 5/1/13.]