

**WAC 296-46B-408 Equipment for general use—Switchboards, switch-gear, and panelboards.** In addition to the requirements of NEC 230.70(A), service equipment, subpanels, and similar electrical equipment must be installed so that they are readily accessible and may not be installed in clothes closets, toilet rooms, or shower rooms.

[Statutory Authority: Chapter 19.28 RCW, RCW 19.28.031 and 19.28.251. WSR 19-15-117, § 296-46B-408, filed 7/23/19, effective 8/23/19.]