

**WAC 296-104-307 Installation—When are platforms around boilers required?** Provide platforms allowing safe access to each boiler, when the controls, valves, manholes, or casing openings are over ten feet above the floor.

[Statutory Authority: RCW 70.79.030, 70.79.040, 70.79.150, 70.79.290, 70.79.330, 70.79.350, and chapter 70.79 RCW. WSR 04-01-194, § 296-104-307, filed 12/24/03, effective 1/24/04; WSR 02-23-036, recodified as § 296-104-307, filed 11/13/02, effective 12/14/02. Statutory Authority: RCW 70.79.030 and 70.79.040. WSR 97-20-109, § 296-104-300, filed 9/30/97, effective 10/31/97; Part V, § 1, filed 3/23/60.]