

**WAC 296-307-34515 Location(s) of manually operated devices.** The employer must ensure that manually operated actuation devices used with employee alarms are easy to find and accessible.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-34515, filed 10/20/20, effective 11/20/20. WSR 97-09-013, recodified as § 296-307-34515, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-34515, filed 10/31/96, effective 12/1/96.]