

WAC 296-307-43013 Fire protection provided for stored containers. Storage locations other than supply depots separated and located apart from dealer, reseller, or user establishments must have at least one approved portable fire extinguisher having a minimum rating of 8-B, C.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-43013, filed 10/20/20, effective 11/20/20. WSR 97-09-013, recodified as § 296-307-43013, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-43013, filed 10/31/96, effective 12/1/96.]